

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the
WATER RESOURCES DEPARTMENT,
SALEM, OREGON
within 30 days from the date
of well completion.

RECEIVED

DEC 5 1978

WATER WELL REPORT

Jose 8800

STATE OF OREGON
(Please type or print)

SALEM, OREGON

State Well No. 37 1/2 W-13ad
State Permit No. 5E N 189 L

(1) OWNER:

Name Clyde Tim
Address 433 Hidden Valley Rd.
Grants Pass, Ore.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 145 ft. Gage 250
" Diam. from " ft. to " ft. Gage
" Diam. from " ft. to " ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used Torch
Size of perforations 1/4 in. by 4 in.
30 perforations from 39 ft. to 145 ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from " ft. to " ft.
Diam. Slot size Set from " ft. to " ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test 20 gal./min. with 150 ft. drawdown after 2 hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered " ft.

(9) CONSTRUCTION:

Well seal—Material used cement
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 9 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 9 sacks
How was cement grout placed?
Was a drive shoe used? Yes No Plugs Size: location " ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: " ft.
Gravel placed from " ft. to " ft.

(10) LOCATION OF WELL:

County Josephine Driller's well number
SE 1/4 NE 1/4 Section 13 T. 37S R. 6W W.M.
Bearing and distance from section or subdivision corner
TL = 109

(11) WATER LEVEL: Completed well.

Depth at which water was first found 140 ft.
Static level 10 ft. below land surface. Date 11-20-78
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 160 ft. Depth of completed well 160 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Granite (Brown)	0	80	—
Granite (Black + White)	80	160	10

Work started 11-16 1978 Completed 11-20 1978
Date well drilling machine moved off of well 11-20 1978

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] James S. Sublette Date 11/21, 1978
(Drilling Machine Operator)
Drilling Machine Operator's License No. 1111

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Coleman's Well Drilling Company
(Person, firm or corporation) (Type or print)
Address 2075 NW Vine grants Pass
[Signed] Joseph P. Blum
(Water Well Contractor)
Contractor's License No. 380 Date 11/21, 1978