NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT.
SALEM, OREGON 97310
within 30 days from the date of well completion.

JOSE 9442

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

State Well No. 36s/5w-21ce

State Permit No. .....

(1) OWNER:
Name John Baldwin
Address 1602 Carnahan Drive.
Grants Pass, Oregon. 97526

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from +1 ft. to 50 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☐ Yes ☒ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
gal./min. with ft. drawdown after hrs.
" " "
" " "
Bailer test 30 gal./min. with 30 ft. drawdown after 1 hrs.
Artesian flow -0- g.p.m.
Temperature of water 54 Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement Slurry
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 13 sacks
How was cement grout placed? Grout Pump

Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? Surface depth of strata 9 To 12
Method of sealing strata off Surface Seal
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Josephine Driller's well number 41
SW ¼ SW ¼ Section 21 T 36 S R 5W W.M.
Bearing and distance from section or subdivision corner
Tax Lot 4902

(11) WATER LEVEL: Completed well.
Depth at which water was first found 45 ft.
Static level 10 ft. below land surface. Date Aug 22, 79
Artesian pressure -0- lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 65 ft. Depth of completed well 65 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Red Clay top soil w/ small gravel	0	12	
Cemmented gravel small to large in size	12	43	
large wash gravel	43	65	10

RECEIVED
NOV 21 1979
WATER RESOURCES DEPT
SALEM, OREGON

Work started Aug 22 1979 Completed Aug 22 1979
Date well drilling machine moved off of well Aug 23 1979

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] William Shaker Date Sept 13, 1979
(Drilling Machine Operator)
Drilling Machine Operator's License No. 905

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name LES SHANAHAN WATER WELL DRILLING CO.
(Person, firm or corporation) (Type or print)
Address 868 N.E. "A" st Grants Pass, Oregon
[Signed] Les Shanahan
(Water Well Contractor)
Contractor's License No. 81 Date Sept 13, 1979

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119