NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

(Do not write above this line)

Jose 9893

State Well No. 34/6W-34ad

State Permit No. .....

(1) OWNER:

Name CLAYTON WEIBLE

Address 848 OXYOKE RD.
GRANTS PASS, OREGON 97526

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
[illegible] ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒

[illegible]6" Diam. from 0 ft. to 22 ft. Gage .250

" Diam. from ft. to ft. Gage

[illegible]" Diam. from 0 ft. to 60 ft. Gage PVC

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.

Type of perforator used SAW CUT

Size of perforations 3/8 in. by 9 in.

60 perforations from 45 ft. to 60 ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a ~~pump~~ air test made? ☒ Yes ☐ No If yes, by whom? DRILLER

[illegible]d: 25 gal./min. with ft. drawdown after 1 hrs.

" " " "

" " " "

Bailer test gal./min. with ft. drawdown after hrs.

[illegible]sian flow g.p.m.

[illegible]erature of water 53 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT

Well sealed from land surface to 20 ft.

Diameter of well bore to bottom of seal 10 in.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal 6 sacks

How was cement grout placed? PUMPED

Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County JOSEPHINE Driller's well number

SE ¼ NE ¼ Section 34 T. 34 R. 6W W.M.

Bearing and distance from section or subdivision corner
TAX LOT 1302
848 OXYOKE RD

(11) WATER LEVEL: Completed well.

Depth at which water was first found 48 ft.

Static level 12 ft. below land surface. Date 7/14/80

Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"

Depth drilled 60 ft. Depth of completed well 60 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
CLAY, BROWN	0	5	
DECOMPOSED GRANITE, BRN	5	48	
TOMBSTONE, FRACTURED	48	60	12
AQUIFER	48	53	25GPM

RECEIVED
AUG 11 1980
WATER RESOURCES DEPT
SALEM, OREGON

Work started 7/14 1980 Completed 7/14 1980

Date well drilling machine moved off of well 7/14 1980

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Randall Antler Date 7/14, 1980
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1352

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name PAQUIN DRILLING INC.
(Person, firm or corporation) (Type or print)

Address 1840 WILLOW LN. GRANTS PASS, OREGON

[Signed] N. Y. Paquin
(Water Well Contractor)

Contractor's License No. 275 Date JULY 15, 1980

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119