

WATER WELL REPORT
STATE OF OREGON

RECEIVED

AUG 20 1980

200
9938

State Well No. 355/LW-2/19c

State Permit No.

WATER RESOURCES DEPT

SALEM, OREGON

(1) OWNER:

Name MILLER REDWOOD CO.
Address P.O. Box 840
City GRANTS PASS State ORE

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven
Rotary Mud Dug
Cable Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other
Thermal: Withdrawal ReInjection

(5) CASING INSTALLED:

Steel Plastic
Threaded Welded
8" Diam. from 0 ft. to 140 ft. Gauge 250
" Diam. from ft. to ft. Gauge

LINER INSTALLED:

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? Yes No
Type of perforator used TORCH
Size of perforations 4 in. by 1/4 in.
40 perforations from 130 ft. to 140 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal/min. with ft. drawdown after hrs.
est 25 gal/min. with drill stem at 299 ft. 2 hrs.
Bailer test gal/min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 540 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes No
Well seal—Material used PORTLAND CEMENT
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 10 sacks
How was cement grout placed? PUMPED

Was pump installed? Type HP Depth ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: ft.
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County JOSEPHINE Driller's well number
SW 1/4 NE 1/4 Section 21 T. 355 R. 6W W.M.
Tax Lot # 200 Lot Blk Subdivision
Address at well location: MERLIN-GAUCE RD.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 130 ft.
Static level 40 ft. below land surface. Date 8-7-80
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 8"
Depth drilled 300 ft. Depth of completed well 300 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
GRAY BOULD/W GRAY CLAY	0'	15'	
BRN CLAY w/ MED GAUZE	15'	85'	40'
BOULDERS w/ BRN. CLAY	85'	95'	40'
CLAY BRN w/ COURSE SAND	95'	130'	40'
BLK & WHT GRANITE w/WHITE MED. HARD.	130'	300'	40'

Work started 7-30 1980 Completed 8-7 1980
Date well drilling machine moved off of well 8-7 1980

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] [Signature] Date 8-13, 1980
(Drilling Machine Operator)
Drilling Machine Operator's License No. 1451

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name COLEMAN'S WELL DRILLING CO.
(Person, firm or corporation) (Type or print)
Address 2075 NW VINE-GRANTS PASS
[Signed] P. Keith Coleman
(Water Well Contractor)
Contractor's License No. 643 Date 8-13, 1980