

17

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

Klam 10261

AUG 27 1991

25S/8E/100

WATER RESOURCES DEPT. (START CARD) # 32731 SALEM, OREGON

(1) OWNER: U.S. Nat. Forest Serv. - Current Water Cares Well Number: Name Address City State Zip

(2) TYPE OF WORK: Recondition

(3) DRILL METHOD: Other Pump Touch

(4) PROPOSED USE: Domestic

(5) BORE HOLE CONSTRUCTION: Depth of Completed Well 280 ft.

HOLE SEAL table with columns for Diameter, From, To, Material, Amount

How was seal placed: Method A B C D E Backfill placed from... Gravel placed from...

(6) CASING/LINER table with columns for Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded

(7) PERFORATIONS/SCREENS: Perforations Screens

Perforations/Screening table with columns for From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner

(8) WELL TESTS table with columns for Yield gal/min, Drawdown, Drill stem at, Time

Temperature of water... Depth Artesian Flow Found... Was a water analysis done?...

(9) LOCATION OF WELL by legal description: County Klamath Township 25 N Range 8 W Section 1 NE 1/4 NE 1/4

(10) STATIC WATER LEVEL: 262 ft. below land surface. Date 8-2-91

(11) WATER BEARING ZONES table with columns for From, To, Estimated Flow Rate, SWL

(12) WELL LOG: THE ORIGINAL WELL LOG SHOWS THE WELL WAS DRILLED TO 285' AND CASSED TO THE BOTTOM WITH 8" X 1250 WALL CASING. OUR PLAN WAS TO PERFORATE FROM 275' TO 285'. WE FOUND THE CASING ONLY WENT TO 250' WE DID NO ALTERATIONS.

Date started 8-2-91 Completed 8-15-91

(unbonded) Water Well Constructor Certification: I certify that the work I performed on the construction, alteration, or abandonment of this well is in compliance with Oregon well construction standards.

(bonded) Water Well Constructor Certification: I accept responsibility for the construction, alteration, or abandonment work performed on this well during the construction dates reported above.