

JAN 2 1987

WATER WELL REPORT

STATE OF OREGON

WATER RESOURCES DEPT. SALEM, OREGON

KLAM 1064

State Well No. 34-8E-34a

State Permit No.

PLEASE TYPE or PRINT IN INK

SHEET # 1 OF 2 SHEETS

(1) OWNER:

Name Tim Mc Call
Address HC 63 Box 564 K
City Chiloquin, OR. 97624 State

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air [X] Driven []
Mud [] Dug []
Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []
Thermal: Withdrawal [] Reinjection []

(5) CASING INSTALLED:

Steel [X] Plastic []
Threaded [] Welded [X]

1.0" Diam. from +1 ft. to 20 ft. Gauge 2.50
" Diam. from ft. to ft. Gauge

LINER INSTALLED:

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? [] Yes [X] No

Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

a pump test made? [] Yes [X] No If yes, by whom? driller
Yield: gal./min. with ft. drawdown after hrs.
Air test 600 gal./min. with drill stem at 60 ft. 1 hrs.
Boiler test gal./min. with ft. drawdown after hrs.
esian flow g.p.m.
Temperature of water 54 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes [] No [X]

Well seal—Material used cement
Well sealed from land surface to 19 ft.
Diameter of well bore to bottom of seal 14 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 10 sacks
How was cement grout placed? Pumped from bottom of seal up to the ground surface.
Was pump installed? No Type HP Depth ft.
Was a drive shoe used? [] Yes [X] No Plugs Size: location ft.
Did any strata contain unusable water? [] Yes [X] No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? [] Yes [X] No Size of gravel: ft.
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Klamath Driller's well number
NE 1/4 NE 1/4 Section 34 T.34 S. R. 8 east W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: HC 63 Box 564 K Chiloquin, OR.
On Sprague River Hwy.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 275 ft.
Static level 22 ft. below land surface. Date 12, 23, 86
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 10"

Depth drilled 353 ft. Depth of completed well 353 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include: Sandy top soil, Yellow clay, Blue clay, Brown sandstone, Blue claystone, Brown clay, Yellow clay with streaks of black sandstone, Brown claystone, Blue clay, Black sandstone, Black rock, Black sandstone, Fractured conglomerate rock, Rock conglomerate, Red and black cinders, Brown sand rock, Red lava rock, Black lava rock, Brown lava rock.

Work started 12, 17, 86 19 Completed 12, 23, 86 19
Date well drilling machine moved off of well 12, 26, 86 19

(unbonded) Water Well Constructor Certification (if applicable):

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Date, 19

Bonded Water Well Constructor Certification:

Bond 20821134 Issued by: Western Surety Co.
(number) Surety Company Name

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Norm Sevey Well Drilling Inc.
(Person, firm or corporation) (Type or print)

Address 5619 Leland Dr. Klamath Falls, OR. 97603

[Signed] Norm Sevey
Water Well Constructor
Date 12, 30, 86, 19

