

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date
of well completion.

REGULATED WATER WELL REPORT

JUN 15 1979 (Please type or print)

WATER RESOURCES DEPT (Do not write above this line)

KLAM
11643

State Well No. 385/9E-92d

State Permit No. G-8625

Corrected by WRD staff

(1) OWNER:

SALEM, OREGON

Name CURTIS T. UNDERWOOD
Address RT 2 BOX 809C
KLAMATH FALLS, ORE

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
" Diam. from ft. to ft. Gage
16" DP " Diam. from 7-1 ft. to 26 ft. Gage 250
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name Model No.
Type Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
DRIFT 1000 GPM @ 610" 2 "

Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.

Temperature of water 58 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT
Well sealed from land surface to 26 ft.
Diameter of well bore to bottom of seal 20 in.
Diameter of well bore below seal in.
Number of sacks of cement used in well seal 24 sacks
How was cement grout placed? POURED

Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County KLAMATH Driller's well number 10
SW 1/4 SW 1/4 Section 9 T. 38S R. 9E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 180 ft.
Static level 106 ft. below land surface. Date 5/22/79
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 15 to 250

Depth drilled 610 ft. Depth of completed well 610 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
BRN CAY TOPSOIL	0	4	
YELLOW CLAY	4	12	
BROKEN BRN BASALT	12	17	
BRN & GRAY BASALT	17	36	
GRAY BASALT	36	48	
BROKEN BRN BASALT	48	67	
GRAY BASALT	67	87	
BROKEN GRAY BASALT Red CINDERS	87	91	
BROKEN BRN BASALT	91	118	
BROKEN GRN BASALT	118	124	
BROKEN BRN BASALT & BRN CINDERS	124	150	
GRAY BASALT	150	180	
GRAY BASALT & Red CINDERS	180	255	NB
GRAY BASALT	255	307	
BRN BASALT	307	325	
GRAY BASALT	325	565	
BROKEN GRAY BASALT	565	570	NB
GRAY BASALT	570	610	

Work started 4/4/79 19 Completed 5/22/79 19
Date well drilling machine moved off of well 5/22/79 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Carl M. Stum Date 6/14, 1979
(Drilling Machine Operator)

Drilling Machine Operator's License No. 656

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name E. E. Staley & Son Well Drilling Inc
(Person, firm or corporation) (Type or print)

Address 3947 HOPE K. FALLS

[Signed] Carl M. Stum
(Water Well Contractor)

Contractor's License No. 601 Date 6/14, 1979