

STATE OF OREGON  
**WATER WELL REPORT**  
 (as required by ORS 537.765)

**KLAMATH RECEIVED**  
 FEB 25 1985  
 PLEASE TYPE or PRINT IN INK  
 WATER RESOURCES DEPT

**RECEIVED**  
 MAR 13 1985  
 385/9E-18dc  
 WATER RESOURCES DEPT  
**SALEM, OREGON**  
 (for official use only)

(1) OWNER: **SALEM, OREGON** (10) LOCATION OF WELL by legal description:

Name Klamath Pacific Corp.  
 Address 2918 Edison  
 City Klamath Falls, State OR. 97603

County Klamath SW 1/4 SE 1/4 of Section 18 of  
 Township 38 south, Range 9 East, WM.  
 (Township is North or South) (Range is East or West)

(2) TYPE OF WORK (check):  
 New Well  Deepening  Reconditioning  Abandon   
 If abandonment, describe material and procedure in Item 12.

Tax Lot \_\_\_\_\_ Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
 MAILING ADDRESS OF WELL (or nearest address) Port of Entry  
Terminal City, HWY North on 97' Klamath  
Falls, Oregon

(3) TYPE OF WELL: (4) PROPOSED USE (check):  
 Rotary Air  Driven  Domestic  Industrial  Municipal   
 Rotary Mud  Dug  Irrigation  Thermal  Reinjection   
 Bored  Other: Piezometric  Grounding  Test

(11) WATER LEVEL OF COMPLETED WELL:  
 Depth at which water was first found 140 ft.  
 Static level 76 ft. below land surface. Date 1, 22, 85  
 Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

(5) CASING INSTALLED: Steel  Plastic   
 Threaded  Welded   
8" Diam. from +1 ft. to 99 ft. Gauge .250  
 \_\_\_\_\_ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gauge \_\_\_\_\_

(12) WELL LOG: Diameter of well below casing 8 inch.  
 Depth drilled 249 ft. Depth of completed well 249 ft.  
 Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

LINER INSTALLED: Steel  Plastic   
 Threaded  Welded   
none  
 \_\_\_\_\_ " Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gauge \_\_\_\_\_

MATERIAL	From	To	SWL
Yellow clay	0	22	
Brown sandstone	22	27	
Yellow clay	27	80	
Brown sandstone	80	94	
Blue clay	94	115	
Gray claystone	115	140	76'
Gray clay	140	152	
Gray claystone with streaks of coarse black sand		171	76'
Soft brown rock	171	190	76'
Black rock	190	197	
Brown clay stone with streaks of brown sand		223	76'
Brown lava rock	223	245	76'
Brown sandstone	245	249	76'

(6) PERFORATIONS: Perforated?  Yes  No  
 Size of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(7) SCREENS: Well screen installed?  Yes  No  
 Manufacturer's Name \_\_\_\_\_  
 Type \_\_\_\_\_ Model No. \_\_\_\_\_  
 Diam. \_\_\_\_\_ Slot Size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Diam. \_\_\_\_\_ Slot Size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom? driller  
 \_\_\_\_\_ ld: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Air 400 GPM with drill stem at 245' 1 hr  
 Air test 200 gal./min. with drill stem at 145' 1 hrs.  
 Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
 Artesian flow \_\_\_\_\_ g.p.m.  
 Temperature of water 60 Depth artesian flow encountered \_\_\_\_\_ ft.

(9) CONSTRUCTION: Special standards: Yes  No   
 Well seal—Material used cement and bentonite  
 Well sealed from land surface to 95 ft.  
 Diameter of well bore to bottom of seal 12 in.  
 Diameter of well bore below seal 8 in.  
 Amount of sealing material 26 cement 2 bentonite  pounds   
 How was cement grout placed? Pumped from bottom of seal  
up to the ground surface.

Was pump installed? NO Type \_\_\_\_\_ HP \_\_\_\_\_ Depth \_\_\_\_\_ ft.  
 Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of Water? none depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_  
 Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
 Gravel placed from none ft. to \_\_\_\_\_ ft.

Date work started 1, 21, 85 /completed 1, 22, 85  
 Date well drilling machine moved off of well 1, 22, 19 85

(unbonded) Water Well Constructor Certification (if applicable):  
 This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
 [Signed] \_\_\_\_\_ Date \_\_\_\_\_, 19 \_\_\_\_\_

(bonded) Water Well Constructor Certification:  
 Bond 20821134 Issued by: Western Surety Co.  
 (number) (Surety Company Name)  
 On behalf of Norm Sevey, Well Drilling, Inc.  
 (type or print name of Water Well Constructor)

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:  
 (Signed) Norm Sevey  
 (Water Well Constructor)  
 (Dated) 1, 28, 85

NOTICE TO WATER WELL CONSTRUCTOR  
 The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,  
 SALEM, OREGON 97310  
 within 30 days from the date of well completion. SP\*46866-690