

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

KLAM  
11694

WATER WELL REPORT

RECEIVED  
MAY 25 1973

STATE OF OREGON STATE ENGINEER

(Please type or print)

(Do not write above this line)

State Well No. 35S/7E-4

State Permit No.

dd

(1) OWNER:

Name Joseph Geamona

Address Hwy. 97.

Chiloquin, Oregon 97624

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
 Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) CASING INSTALLED:

Threaded  Welded

6" Diam. from 0 ft. to 38' 6" ft. Gage 250

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated?  Yes  No.

Type of perforator used

Size of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?

gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test 30 gal./min. with 5 ft. drawdown after 2 hrs.

Artesian flow g.p.m.

Temperature of water 58 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used cement and bentonite

Well sealed from land surface to 38' 6" ft.

Diameter of well bore to bottom of seal 8 in.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal one sacks

Number of sacks of bentonite used in well seal one sacks

Brand name of bentonite Aqua-Gel

Number of pounds of bentonite per 100 gallons

of water 100 lbs./100 gals.

Was a drive shoe used?  Yes  No Plugs Size: location ft.

Did any strata contain unusable water?  Yes  No

Type of water depth of strata

Method of sealing strata off

Was well gravel packed?  Yes  No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Klamath

Driller's well number

SE 1/4 SE 1/4 Section 4 T. 35S R. 7E W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 155 ft.

Static level 62 ft. below land surface. Date 5, 4, 73

Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6 inch.

Depth drilled 167 ft. Depth of completed well 167 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
top soil	0	4	
broken rock and brown clay	4	8	
yellow clay	8	32	
blue clay	32	150	
blue clay and gravel mix	150	155	62'
black lava rock	155	165	
cracked black lava rock	165	167	62'

Work started 4, 30, 1973 Completed 5, 4, 1973

Date well drilling machine moved off of well 5, 4, 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Norman Sevey Date 5, 23, 1973  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 196

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Norm Sevey Well Drilling  
(Person, firm or corporation) (Type or print)

Address 5619 Leland Dr. Klamath Falls, Oregon. 97601

[Signed] Norman Sevey  
(Water Well Contractor)

Contractor's License No. 408 Date 5, 23, 1973