

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

KLAMATH
1176

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
STATE ENGINEER
(Do not write above this line)

RECEIVED
APR 26 1973
State Well No. 355/7E-6
State Permit No.

(1) OWNER:

Name Robert M. Perla
Address 1922 Stradella Rd.
Los Angeles, Calif. 90024

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
16" Diam. from 1 ft. to 63 ft. Gage # 250
10" Diam. from 2 ft. to 226 ft. Gage # 250

PERFORATIONS:

Perforated? Yes No.
Type of perforator used Torch
Size of perforations 16 in. by 6 in.
7 rows - 21 perforations from 166 ft. to 226 ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Valley Pump Co.
Yield: 560 gal./min. with 81 ft. drawdown after 24 hrs.
Bailer test 100 gal./min. with no ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m.
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 62 ft.
Diameter of well bore to bottom of seal 20 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 48 sacks
Number of sacks of bentonite used in well seal none sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: 1/4
Gravel placed from 0 ft. to 140 ft.

(10) LOCATION OF WELL:

County Klamath Driller's well number 2
Govt. Lot, Section 6 T. 35 R. 7 E. W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 135 ft.
Static level 119 ft. below land surface. Date 3/28/73
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 10
Depth drilled 280 ft. Depth of completed well 280 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
0 ft. - 4 ft. Top Soil	0	4	
Cemented Gravel	4	7	
Clay	7	21	
Brown Shale	21	60	
Brown Hard Shale	60	65	
Brown Bank Sand	65	103	
Blue Clay	103	112	
1st W. Black Sand (med)	112	114	
Brown Sand (Coars) Sta. W.	114	136	99'
Brown Sand (fine)	136	172	
Brown Clay (packed)	172	187	
Black Sand	187	209	
Blue Clay & Rock	209	215	
Lava Rock (Hard)	215	244	
Coarse Gravel	244	246	119'
Hard Rock	246	280	

Work started Feb 5 1973 Completed Apr. 3 1973
Date well drilling machine moved off of well Apr. 3 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Charles E. Hartley Date Apr. 17, 1973
(Drilling Machine Operator)
Drilling Machine Operator's License No. 2333

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Charles E. Hartley Well Drilling
(Person, firm or corporation) (Type or print)
Address 4779 South Sixth St
Klamath Falls Oregon 97601
[Signed] Charles E. Hartley
(Water Well Contractor)
Contractor's License No. 145 Date Apr. 17, 1973