

(1) OWNER: VAUGHN LMB Co. (1963)
Name Weyerhaeuser Timber Co., K.F. Brands
Address Klamath Falls, Or.

(10) WELL TESTS: KLAM 11769
Was a pump test made? Yes No If yes, by whom?
Yield: 225 gal./min. with 70 ft. draw down after 3 hrs.
" " " " "
" " " " "
Artesian flow _____ g.p.m.
Shut-in pressure _____ lbs. per square inch.
Bailer test _____ g.p.m. with _____ ft. drawdown
Temperature of water _____ Was a chemical analysis made? Yes No
Was electric log made of well? Yes No

(2) LOCATION OF WELL:
County Klamath Owner's number, if any _____
R. F. D. or Street No. [Yamsay "Antelope"]
Bearing and distance from section or subdivision corner
446 ft. S. 10° 23' W from N.E. corner
Sec. 7, T. 29 S., R. 8 E., W.M.

(11) WELL LOG:
Diameter of well, _____ inches.
Total depth _____ ft. Depth of completed well _____ ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

(3) TYPE OF WORK (check):
New well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 11.
(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) EQUIPMENT:
Rotary
Cable
Dug Well

CASING INSTALLED:
Threaded Welded

FROM	ft.	to	ft.	Diam.	Gage or Wall	Diameter of Bore	from	to
0	"	135	"	7 in.	.250			

If gravel packed _____
Type and size of shoe or well ring _____ Size of gravel: _____
Describe joint _____

ft.	to	ft.	Description
0	"	52	pumice and lava boulders
52	"	135	lava rock broken and loose
"	"	"	"
"	"	"	"
"	"	"	"
"	"	"	"
"	"	"	"
"	"	"	"
"	"	"	"
"	"	"	"
"	"	"	"
"	"	"	"
"	"	"	"
"	"	"	"
"	"	"	"
"	"	"	"
"	"	"	"
"	"	"	"
"	"	"	"
"	"	"	"

(7) PERFORATIONS:
Type of perforator used _____
SIZE of perforations 3/8 in., length, by 5 in.
FROM ft. to ft. perf per foot No. of wires
00 " 135 " 1 1/2 " 6 "

SCREENS:
Give Manufacturer's Name, Model No. and Size _____

(8) CONSTRUCTION:
Was a surface sanitary seal provided? Yes No To what depth 100 ft.
Were any strata sealed against pollution? Yes No
If yes, note depth of strata _____
FROM ft. to ft.
" " "
METHOD OF SEALING Cement

Ground elevation at well site _____ feet above mean sea level.
Work started July 19 ____ , Completed Aug. 19 ____

(9) WATER LEVELS:
Depth at which water was first found 103 ft.
Standing level before perforating 103 ft.
Standing level after perforating 103 ft.
Log Accepted by:
Signed Weyerhaeuser Timber Co. Dated Aug. 13, 1957
A. M. Harrington owner

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME W.L. Hartley & Son (Person, firm, or corporation) (Typed or printed)
Address Bonanza Oregon
Driller's well number _____
[Signed] Robert F. Hartley (Well Driller)
License No. 104 Dated Aug. 12, 1957