

RECEIVED

JAN 08 1986

KLAMATH
11824

38/9E-20dd

STATE OF OREGON
WATER WELL REPORT WATER RESOURCES DEPT
(as required by ORS 537.765)
SALEM, OREGON

(1) OWNER: Frank Della Rosa
Name
Address 1834 Benson
City Klamath Falls, State OR, Zip 97601
Owner's Well Number:

(2) TYPE OF WORK:
 New Well Deepen Recondition Abandon

(3) DRILL METHOD:
 Rotary Air Rotary Mud Cable Other

(4) PROPOSED USE:
 Domestic Community Industrial Irrigation
 Thermal Injection Other

(5) BORE HOLE CONSTRUCTION:
Depth of Completed Well 929 ft.
Special Standards date of approval

Table with columns: HOLE Diameter, From, To, SEAL Material, From, To, Amount sacks or pounds. Row 1: 12" 0 334 cement 0 332 144 sacks. Row 2: 8" 334 929

How was seal placed? Method A B C D E
 Other

Backfill placed from ft. to ft. Material
Gravel placed from ft. to ft. Size of gravel

(6) CASING/LINER: Table with columns: Diameter, From, To, Gauge, Steel, Plastic, Welded, Threaded. Casing: 8" 334 .250. Liner: 6" 319 .250

Final location of shoe(s)
(7) PERFORATIONS/SCREENS:

Table with columns: From, To, Slot size, Number, Diameter, Tele/pipe size, Casing, Liner. Rows for perforations at 489-531, 655-675, 757-799, 819-841, 862-883.

(8) WELL TESTS: Minimum testing time is 1 hour
 Pump Bailer Air Flowing Artesian
Yield gal/min 30 Pumping level 165' Drill stem at 165' Time 4 1/2 Hrs

Temperature of water 170° Depth Artesian Flow Found
Was a water analysis done? Yes By whom
Did any strata contain water not suitable for intended use? Too little
 Salty Muddy Odor Colored Other Not hot enough
Depth of strata: 299 to 312'

(9) LOCATION OF WELL by legal description:
County Klamath Latitude Longitude
Township 38 south N or S, Range 9 east E or W, WM.
Section 20 SE 1/4 SE 1/4
Tax Lot Lot Block Subdivision
Street Address of Well (or nearest address) 1834 Benson
Klamath Falls, OR.

(10) STATIC WATER LEVEL:
ft. below land surface. Date
Artesian pressure lb. per square inch. Date

(11) WELL LOG: Ground elevation

Table with columns: Material, From, To, WB?, SWL. Rows include Top soil, Brown clay & gravel, Yellow clay, Blue clay, Sandy gray clay, Brown clay, Blue clay, Soft brown clay, Blue clay, Reddish gray clay, Gray rock and clay, Gray rock with voids, Reddish gray clay, Soft gray shale, Soft green clay, Hard gray & blue conglom., Gray sandstone with pyrite and quartz, Hard gray conglomerate, Reddish brown shale, Hard gray conglomerate, Gray sandstone with pyrite and quartz, Hard gray conglomerate, Gray & red conglomerate, Void (no returns), Gray, red, & blue quartz, Loss zone, Gray, red, & blue quartz and conglomerate.

Date started 5, 14, 85 Completed 12, 13, 85

(unbonded) Water Well Constructor Certification:
I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.
Signed Date

(bonded) Water Well Constructor Certification:
I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.
Signed Norm Sevey Date 1, 4, 86
Company Norm Sevey Well Drilling Co. Job No.