NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the <b>WATER WE</b>	LL REPORT	285/05 0000			
are to be filed with the WATER WELL REPORT WATER RESOURCES DEPARTMENT. SALEM, OREGON 97310 Within 30 days from the date of well completion. (Do not write above this line) WATER WELL REPORT (Please type or print) (Do not write above this line)					
			(1) OWNER:	(10) LOCATION OF WELL:	
(1) OWNER.	. County KLAMATH Driller's well number NE 145W14 Section 20 T. 38S R. 9E W.M.				
Name MOUNTAIN VIEW PROFESSIONAL BULLONG SSSN. Address 3949 5 6th ST KLAMATH FALLS, ORE					
Address 3949 J 6 J ALAMAIN FALL ONE					
	Bearing and distance from section or subdivis	sion corner			
(2) TYPE OF WORK (check):					
New Well 🗙 Deepening 🗌 Reconditioning 🗌 Abandon 🗋					
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.				
(3) TYPE OF WELL: (4) PROPOSED USE (check):	- 4.14				
Botary 12 Driven []					
Cable 🗍 Jetted 🔲 Domestic 🗋 Industrial 🗋 Municipal 📋					
Bored 🗌 Irrigation 🗌 Test Well 🗌 Other					
(5) CASING INSTALLED: Threaded D Welded					
(5) CASING INSTALLED: Threaded $\square$ Welded $\square$ 8.24" Diam. from $\pm 1$	(12) WELL LOG: Diameter of well below casing Depth drilled 3/4/ ft. Depth of completed well 3/0 ft.				
5.75 "Diam. from $1$ ft. to $3.14$ ft. Gage $150$					
"Diam. fromft. toft. Gage	Formation: Describe color, texture, grain size and structure of materials				
Diam. tromft. Gage	and show thickness and nature of each stratum and aquifer penetrated				
(6) PERFORATIONS: Perforated? Ves UN	with at least one entry for each change of forma position of Static Water Level and indicate pri	ation. Report each change in			
(6) PERFORATIONS: Perforated? XYes □ No. Type of perforator used FACTORY		T			
	MATERIAL	From To SWL			
Size of perforations // in. by 3 in.	BOULDERSY RASTICKY CLAY	0 7			
328 perperations from 114 ft. to 134 ft.	HARd BROW CHALK ROCK	7 25			
45 k perforations from 274 ft. to 314 ft.	Vellow SHALE	25 42			
	BROWN SKALE	42 117			
(7) SCREENS: Well screen installed?	HARD BAN CHALK ROCK	117 120			
	HARd BAK CHALK ROCK	120 123			
Manufacturer's Name	HARDBAKTUFF	123 171			
Type Model No.	GRAY CLAY	171 186			
Diam. Slot size	BLK TUFF & STARS QRAY CLAY	186 288			
Diam Slot size Set from ft. to ft.	HARd BLY TUFF	288 304			
(8) WELL TESTS: Drawdown is amount water level is	STICK GRAY CLAY	304 307			
lowered below static level	HARD BROKEN BLKTUFF	307 314 WB			
Was a pump test made?  Yes No If yes, by whom?					
d: gal./min. with ft. drawdown after hrs.					
AIRLIFT ASD GPM@ 320 " 2"					
11 11 ji n	AFT 171980				
Bailer test gal./min, with ft. drawdown after hrs.	WATER RESOURCES DEPT				
	SALEM, OREGON				
Temperature of water 74 Depth artesian flow encountered ft.	Work started 3/25/87 19 Complet	ed 3 /3//80 19			
(9) CONSTRUCTION:	Date well drilling machine moved off of well	3/31/80 19			
O PARA T					
32	Drilling Machine Operator's Certification:				
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used and information reported above are true to my				
Diameter of well bore to bottom of seal $2$ in.	best knowledge and belief				
Diameter of well bore below seal	[Signed] (Drilling Machine Operator) Date 4/14, 1980				
Number of sacks of cement used in well seal	Drilling Machine Operator) Drilling Machine Operator's License No. 656				
How was cement grout placed?					
	Water Well Contractor's Certification:				
	an in the second s				
	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.				
Was a drive shoe used? Yes [] No Plugs	Name EESTOREYNSONWELLDRILL, NO'NE				
Did any strata contain unusable water? 🗌 Yes 🗋 No	(Person, firm or corporation) (Type or print)				
Type of water? depth of strata	Address 3847, HOPE NEALLS, OKC				
Method of sealing strata off	12-1)m A				
Was well gravel packed? [] Yes 🗙 No Size of gravel:	[Signed] (Water Well Contr	actor			
	Contractor's License No. 60 / Date	19.00			
(USE ADDITIONAL SH	EETS IF NECESSARY)	SP*45858-119			
	·				