

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

APR 26 1968

STATE OF OREGON (Please type or print)

(Do not write above this line)

STATE ENGINEER SALEM OREGON

KLAM 1200

State Well No. 35/7-7P

State Permit No. G-4233

(1) OWNER: Milton F. VanVoorhis (uac)

Name Milton L. Voarhese

Address 8371 Country Club Drive Buena Park, Calif. 90620

(2) TYPE OF WORK (check):

New Well [x] Deepening [ ] Reconditioning [ ] Abandon [ ]

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [x] Jetted [ ] Dug [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [x] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ]

CASING INSTALLED:

Threaded [ ] Welded [x] 1 1/2" Diam. from 0 ft. to 40 ft. Gage 250. 8" Diam. from 0 ft. to 130 ft. Gage 250.

PERFORATIONS:

Perforated? [x] Yes [ ] No

Type of perforator used Torch

Size of perforations 16 in. by 4 in. 187 perforations from 90 ft. to 120 ft.

(7) SCREENS:

Well screen installed? [ ] Yes [x] No

Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well. 1967

Static level 26 ft. below land surface Date Aug 15 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [x] Yes [ ] No If yes, by whom? Driller

Yield: 250 gal./min. with 80 ft. drawdown after 4 hrs.

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water 53 Was a chemical analysis made? [ ] Yes [x] No

(10) CONSTRUCTION:

Well seal—Material used Cement & Bentonite

Depth of seal 40 ft.

Diameter of well bore to bottom of seal 16 in.

Were any loose strata cemented off? [ ] Yes [x] No Depth

Was a drive shoe used? [x] Yes [ ] No

Did any strata contain unusable water? [ ] Yes [x] No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? [x] Yes [ ] No Size of gravel: Pgs

Gravel placed from 0 ft. to 120 ft.

(11) LOCATION OF WELL:

County Klamath Driller's well number 67012 Section 7 T35S. R.7EWM W.M.

Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 8"

Depth drilled 250 ft. Depth of completed well 250 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include: Fine Yellow Sand, Blue Clay, Blue Sand Med., Blue Clay, Blue Sand Course to 1/2", Gravel, Blue Clay, Course. Sand W. B., Blue Clay.

Work started 7/15 1967 Completed 8/18 /6 719

Date well drilling machine moved off of well 8/20 /67 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Charles E. Hartley Date 8/30/1967 (Drilling Machine Operator)

Drilling Machine Operator's License No. 233.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Charles E. Hartley (Person, firm or corporation) (Type or print)

Address 47 79 1/2 S. 6TH. Klamath Falls Oregon

[Signed] Charles E. Hartley (Water Well Contractor)

Contractor's License No. 145 Date 8/30/1967