

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy of this report
 are to be filed with the
 WATER RESOURCES DEPARTMENT,
 Salem, Oregon 97310
 within 30 days from the date
 of well completion.

*Klamath
2089*
1

WATER WELL REPORT

STATE OF OREGON
 (Please type or print)

(Do not write above this line)

State Well No. 38S/9E-32
 State Permit No. Revised

(1) OWNER:

Name City of Klamath Falls, (Water Department)
 Address 7th Pine Street
Klamath Falls, Oregon 97601

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
 16" Diam. from 2 plus ft. to 105 ft. Gage 375
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____
 Size of perforations in. by in.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. Slot size Set from ft. to ft.
 Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? _____
 Yield: gal./min. with ft. drawdown after hrs.
 " " " " " "
 " " " " " "
 Bailor test gal./min. with ft. drawdown after hrs.
 Artesian flow g.p.m. _____
 Temperature of water 64 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used cement
 Well sealed from land surface to 103 ft.
 Diameter of well bore to bottom of seal 20 in.
 Diameter of well bore below seal 20 to 130 feet
 Number of sacks of cement used in well seal 648 sacks
 How was cement grout placed? pumped in.
 Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Klamath Driller's well number _____
 1/4 1/4 Section 32 T. 38S R. 9E W.M.
 Bearing and distance from section or subdivision corner
California Avenue
K Falls Ore 9.1

(11) WATER LEVEL: Completed well.

Depth at which water was first found _____ ft.
 Static level 9 ft. below land surface. Date 5/4/79
 Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG: 103 to 130 16 in 130 to 368 10 in

Depth drilled _____ ft. Diameter of well below casing _____ ft.
 Depth of completed well _____ ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Old 13 inch casing drilled out and then pulled out. 63 feet of 13 inch casing pulled out.			
105 feet of 16 inch casing installed.			
Well was cleaned out to 368 feet.			
Before casing was installed. (New 16 in) The well was checked to pump 3200 G.P.M.			

Work started Mar 17 19 79 Completed May 3 19 79
 Date well drilling machine moved off of well May 4 19 79

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
 [Signed] Walter L Wilson Date May 4, 19 79
 (Drilling Machine Operator)
 Drilling Machine Operator's License No. 201

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
 Name Wilson Drilling Contractor Inc.
 (Person, firm or corporation) (Type or print)
 Address P.O. Box 136, Merrill, Oregon 97633
 [Signed] Walter L Wilson
 (Water Well Contractor)
 Contractor's License No. 169 Date May 4, 19 79