

ORIGINAL  
File Original and  
Duplicate with the  
STATE ENGINEER,  
SALEM, OREGON

RECEIVED JUN 10 1958 WATER WELL REPORT STATE OF OREGON

KLAM 12121

State Well No. G 861 38/9-32E(8)  
State Permit No. G 756

(1) OWNER:  
Name OREGON WATER CORPORATION  
Address 630 CONGER AVENUE  
KLAMATH FALLS, OREGON

STATE ENGINEER SALEM, OREGON

(11) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Interstate  
Yield: 4500 gal./min. with 41 1/2 ft. drawdown after 4 hrs.  
" " " "  
" " " "  
" " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water 68 Was a chemical analysis made?  Yes  No

X (2) LOCATION OF WELL:  
County KLAMATH Owner's number, if any—  
S.W. 1/4 N.W. 1/4 Section 32 T. 38 S R. 9 E. W.M.  
Bearing and distance from section or subdivision corner  
2163.27' S. 1342.60' W. from the N. 1/4 corner  
of section 32, T. 38 S. R. 9 E. W.M.

(12) WELL LOG: Diameter of well 18" inches.  
Depth drilled 435 ft. Depth of completed well 433 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

(3) TYPE OF WORK (check):  
Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

MATERIAL	FROM	TO
top soil	0	7
brown basalt boulders	7	30
clay and boulders	30	80
boulders and clay (water flow)	80	85
clay and boulders	85	96
basalt boulders (reduced hole 20 to 18 @ 97')	96	100
black basalt	100	185
gray basalt	185	227
brown sticky shale with rock shells	227	276
blue shale	276	295
brown sticky shale	295	331
brown sticky shale with rock shells	331	362
black basalt (water flow)	362	368 1/2
broken hard basalt	368 1/2	377
hard conglomerate	377	385
yellow clay	385	388
basalt crevice	388	391
sticky brown shale with rock shells	391	424
black basalt	424	435

(4) PROPOSED USE (check): Domestic  Industrial  Municipal   
Irrigation  Test Well  Other   
(5) TYPE OF WELL:  
Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED: Threaded  Welded   
18" OD Diam. from plus 1 ft. to 117 ft. Gage 1/4"  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated?  Yes  No  
Type of perforator used  
SIZE of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

(8) SCREENS: Well screen installed  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.  
Was a surface seal provided?  Yes  No To what depth? ft.  
Material used in seal—  
Did any strata contain unusable water?  Yes  No  
Type of water? Depth of strata  
Method of sealing strata off

(10) WATER LEVELS:  
Static level 6" below land surface Date 6/5/58  
Artesian pressure lbs. per square inch Date

(13) PUMP:  
Manufacturer's Name  
Type: H.P.

Well Driller's Statement:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME E.E. Storey Well Drilling (Person, firm, or corporation) (Type or print)  
Address 4237 Summers Lane, Klamath Falls  
Driller's well number  
[Signed] E.E. Storey (Well Driller)  
License No. 74 Date 6/9, 1958

Log Accepted by:  
X [Signed] Glenn S. Rowen Date June 9, 1958  
(Owner) VICE PRES.