

ORIGINAL
File Original and
Duplicate with the
STATE ENGINEER,
SALEM, OREGON

RECEIVED
OCT 16 1957

WATER WELL REPORT
STATE OF OREGON

KLAM
12148

State Well No. 38/9-33 G (2)
State Permit No. _____

(1) OWNER:

Name Mills Elementary School
Address East Main and Orchard Ave.
Klamath Falls, Oregon

(2) LOCATION OF WELL:

County Klamath Owner's number, if any—
1/4 Section T. R. W.M.
Bearing and distance from section or subdivision corner
East Main and Orchard Ave.

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow 100 g.p.m. Date 9/13
Temperature of water 18.2° Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 8 inches.
Depth drilled 809 ft. Depth of completed well 809 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

| MATERIAL | FROM | TO |
|---------------------------------|------|-----|
| Clay and gravel | 0 | 65 |
| Sandstone | 65 | 75 |
| Clay and gravel | 75 | 150 |
| Green shale | 150 | 290 |
| Green shale with shells of rock | 290 | 340 |
| Green shale | 340 | 535 |
| Green shale with layers of rock | 535 | 540 |
| Brown shale with layers of rock | 540 | 604 |
| Gray basalt | 604 | 623 |
| Sticky brown shale | 623 | 695 |
| Gray shale | 695 | 719 |
| Coarse sand | 719 | 724 |
| Gray basalt | 724 | 749 |
| Gray shale | 749 | 755 |
| Black basalt | 755 | 760 |
| Black basalt crevices | 760 | 778 |
| Brown shale | 778 | 780 |
| Gray basalt | 780 | 797 |
| Black basalt (hard) | 797 | 809 |

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8 1/8" Diam. from -2 1/2 ft. to 609 1/2 ft. Gage 5/16
6 3/8" Diam. from 599 ft. to 809 ft. Gage 1/4
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used _____
SIZE of perforations in. by in.
80 perforations from 769 ft. to 809 ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

SCREENS:

Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
_____ Slot size _____ Set from _____ ft. to _____ ft.

CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 609 ft.
Material used in seal— DRILL CUTTINGS
Did any strata contain unusable water? Yes No
Type of water? COLD Depth of strata 65
Method of sealing strata off CASING

(10) WATER LEVELS:

Static level _____ ft. below land surface Date _____
Artesian pressure 2 1/2 lbs. per square inch Date 9/13/57

Log Accepted by:

[Signed] School Dist No 1 Date Sept 27, 1957
Howard R. [Signature]
deluted

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME E.E. Storey Well Drilling
(Person, firm, or corporation) (Type or print)

Address 4237 Summers Lane, Klamath Falls, Ore.

Driller's well number #2

[Signed] [Signature]
(Well Driller)

License No. 74 Date 9/25, 1957