

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy of this report are to be filed with the

RECEIVED WATER WELL REPORT RECEIVED

WATER RESOURCES DEPARTMENT  
SALEM, OREGON 97310  
within 30 days from the date of well completion.

JAN 23 1981

STATE OF OREGON  
(Please type or print)

MAR 27 1981

State Well No. 385/9E-35d

WATER RESOURCES DEPT  
SALEM, OREGON

WATER RESOURCES DEPT  
SALEM, OREGON

(1) OWNER:

Name City of Klamath Falls  
Address Klamath Falls, Oregon

(2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary  Cable  Dug   
Driven  Jetted  Bored

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

CASING INSTALLED:

Threaded  Welded   
26" Diam. from 0 ft. to 37 ft. Gage 375  
16" Diam. from 0 ft. to 422 ft. Gage 250

PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used sawed  
Size of perforations 1/8 in. by 2 1/2 in.  
11,520 perforations from 62 ft. to 422 ft.

(7) SCREENS:

Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Interstate Pump  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: 750 gal./min. with 194 ft. drawdown after 69 hrs.  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m.  
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used cement grout  
Well sealed from land surface to 37 ft.  
Diameter of well bore to bottom of seal 34 in.  
Diameter of well bore below seal 24 in.  
Number of sacks of cement used in well seal 4 yds sacks  
How was cement grout placed? Grout Pump  
Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel: 3/8-3/4  
Gravel placed from 0 ft. to 422 ft.

(10) LOCATION OF WELL:

County KLAMATH Driller's well number  
1/4 SE 1/4 Section 35 T. 38S R. 9E W.M.  
Bearing and distance from section or subdivision corner  
Homedale Rd. N Shasta Way

(11) WATER LEVEL: Completed well.

Depth at which water was first found 135 ft.  
Static level 33 ft. below land surface. Date  
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing  
Depth drilled 427 ft. Depth of completed well 422 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top Soil	0	4	
Hard Pan	4	7	
Coarse Dry Sand	7	28	
Brown Clay & Sand	28	85	
Black Clay & Sand	85	135	
Black Sandy Clay	135	170	
Blue Green Clay	170	230	
Yellow Hard Clay	230	240	
Yellow Sandy Clay	240	266	
Black Clay	266	358	
Fine black sand & blue clay	358	410	
Blue black clay—some hard streaks (clay)	410	530	

Work started 12/29 1980 Completed 1/14/ 1981  
Date well drilling machine moved off of well 1/14 1981

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Michael Campbell Date 1-12, 1981  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 1445

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name City of Klamath Falls  
(Person, firm or corporation) (Type or print)  
Address P.O. Box 237  
[Signed] Tom Barnes  
(Water Well Contractor)  
Contractor's License No. Date 1-19, 1981