

RECEIVED
 SEP 12 1961
 STATE ENGINEER
 SALEM, OREGON

File Original and
 First Copy with the
 STATE ENGINEER,
 SALEM, OREGON

WATER WELL REPORT
 STATE OF OREGON

KLAM
12183

State Well No. 3879-36
 State Permit No. _____

(1) OWNER:

Name Martin & Craig
 Address 1754 Kenneth
Klamath Falls Ore

(2) LOCATION OF WELL:

County Washburn Owner's number, if any— 2
S 1/4 SE 1/4 Section 36 T. 38 S R. 9 E W.M.
 Bearing and distance from section or subdivision corner
N. 35° 49' E - 1444 feet from
corner S 36 and Sec. 1 - T. 39 S
R 9 E

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
 " Diam. from 2 ft. to 10.9 ft. Gage 250
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used _____
 SIZE of perforations in. by in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
 Manufacturer's Name _____
 Type _____ Model No. _____
 _____ Slot size _____ Set from _____ ft. to _____ ft.
 _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Was a surface seal provided? Yes No To what depth? _____ ft.
 Material used in seal— cement
 Did any strata contain unusable water? Yes No
 Type of water? good Depth of strata _____
 Method of sealing strata off cessant

(10) WATER LEVELS:

Static level 354 ft. below land surface Date _____
 Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by: _____

[Signed] _____ Date _____, 19____
 (Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom? Martin
 Yield: 110 gal./min. with 5 ft. drawdown after 7 hrs.
 " " " "
 " " " "
 " " " "
 " " " "
 " " " "
 " " " "
 " " " "
 " " " "
 " " " "
 " " " "
 " " " "
 " " " "

(12) WELL LOG:

Diameter of well 16 inches.
 Depth drilled 1100 ft. Depth of completed well 1100 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Clay & Balders	0	23
dry sand	23	100
sandstone	100	108
Bay salt rock	108	168
sandstone hard	168	176
sandstone	176	204
large rock	204	244
heavily	244	740
Clay & rock	740	905
rock	905	935
clay	935	980
Bay salt rock	980	1040
clay	1040	1070
Red Bluff rock	1070	1100

Work started May 8 1961 Completed Aug 1961

(13) PUMP:

Manufacturer's Name Vela
 Type: submersible H.P. 20

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W.L. Hartley & Son (Type or print)
 (Person, firm, or corporation)

Address Bananza Ore

Driller's well number _____

[Signed] W.L. Hartley (Well Driller)

License No. 164 Date Aug, 1961