

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97330 within 30 days from the date of well completion.

RECEIVED
APR 27 1970

WATER WELL REPORT

STATE OF OREGON
STATE ENGINEER
SALEM, OREGON

(Please type or print)

(Do not write above this line)

*KLAM
12184*

State Well No. 38/9-36 ca

State Permit No. _____

(1) OWNER:

Name FIRST ADDITION TO MOYINA IMPROVEMENT DIST.
Address 400 PINE ST. KLAMATH FALLS ORE

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
" Diam. from 7.1 ft. to 10.3 ft. Gage 250
10.34 " Diam. from 7.18 " to 5.70 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No
Type of perforator used FACTORY (SLOT)
Size of perforations 5/32 in. by 2 in.
32 PERFORATIONS from _____ ft. to _____ ft.
32 PERFORATIONS from 201 ft. to 570 ft.
with 10 perforations solid pipe
perforations from _____ ft. to _____ ft.
perforations from EXAMPLE ft. to DISPERIA ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 154 ft. below land surface Date 4/3/70
 Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? VALEY PUMP
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
230 " 96 " 4 "

Bailer test

gal./min. with _____ ft. drawdown after _____ hrs.

Artesian flow

g.p.m. Date _____

Temperature of water 63

Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used CEMENT
Depth of seal 104 ft.
Diameter of well bore to bottom of seal 17 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: 1/4-3/8
Gravel placed from 0 ft. to 570 ft.

(11) LOCATION OF WELL:

County KLAMATH Driller's well number _____
NE 1/4 SW 1/4 Section 36 T. 38 S. R. 9 E W.M.
Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing 0
Depth drilled 570 ft. Depth of completed well 570 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Boulders	0	5	
PACKED SAND	5	42	
CAVING SAND	42	51	
PACKED SAND	51	85	
BROWN SHALE	85	105	
BROWN SANDSTONE	105	150	
OPEN Hole	150	190	
BROWN SANDSTONE	190	295	
BLUE CLAY	295	326	
BROWN SHALE	326	367	
BLUE STICKY CLAY	367	413	
BROWN SAND	413	434	
GREEN SANDY SHALE	434	565	
GREEN SHALE	565	570	

Work started 2/24/70 19 Completed 4/3/70 19
Date well drilling machine moved off of well 4/3/70 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] E. E. Storey Date 4/26/70 19
(Drilling Machine Operator)

Drilling Machine Operator's License No. 115

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME E. E. Storey
(Person, firm or corporation) (Type or print)

Address 3831 HOPE N FALLS

[Signed] E. E. Storey
(Water Well Contractor)

Contractor's License No. 74 Date 4/26/70 19