

RECEIVED

RECEIVED

KLAM 12185

38/9-36

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

OCT 2 1962 WATER WELL REPORT

OCT 24 1962

STATE ENGINEER, SALEM 10, OREGON STATE ENGINEER STATE Well No. STATE PERMIT No. G-2443 SALEM, OREGON

(1) OWNER: Name C.E. McCLELLAN Address 1290 PATTERSON ST.

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? X Yes No If yes, by whom? DALWATER Yield: 225 gal./min. with 45 ft. drawdown after 5 hrs.

(2) LOCATION OF WELL: County Klamath Driller's well number NE 1/4 SW 1/4 Section 36 T. 38S. R. 7E. W.M. 30 FT. NORTH McCLELLAN DRIVE IN MOYINA HGT.

Bailer test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water 58 Was a chemical analysis made? No

(3) TYPE OF WORK (check): New Well X Deepening Reconditioning Abandonment

(12) WELL LOG: Diameter of well below casing 10" Depth drilled 580 ft. Depth of completed well 580 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

(4) PROPOSED USE (check): Domestic Industrial X Municipal Irrigation Test Well Other

(5) TYPE OF WELL: Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED: 10 3/4" Diam. from 2 ft. to 90 ft. Gage 250

Table with columns MATERIAL, FROM, TO. Rows include TOP SOIL SANDY LOAM, LAVA BOULDERS + HARD ROCK, BROWN SAND, BLUE BASALT BOULDERS, BROWN SAND, LAVA BOULDERS, BROWN SAND FIRST WATER, BROWN CLAY, BLUE CLAY, BROWN STICKY CLAY, PEA GRAVEL, BLUE STICKY CLAY, BLUE SAND COURSE, BLUE HARD SHALE, BLUE LAVA ROCK, GREY CLAY, STICKY BLACK CLAY, BLUE SAND & GRAVEL, GREY CLAY, FINE BROWN SAND, SOME CLAY. Includes handwritten note: 'I RECOMMEND THIS WELL BE CASED TO THE BOTTOM'

(7) PERFORATIONS: Perforated? No Type of perforator used Size of perforations in. by in.

(8) SCREENS: Well screen installed No Manufacturer's Name Time Slot size Set from ft. to Diam. Slot size Set from ft. to

Work started Aug 7 1962 Completed SEPT 10 1962 Date well drilling machine moved off of well SEPT 15 1962

(9) CONSTRUCTION: Well seal—Material used in seal CEMENT Depth of seal 80 ft. Was a packer used? No Diameter of well bore to bottom of seal 12 in. Were any loose strata cemented off? No Depth Was a drive shoe used? Yes No Was well gravel packed? No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? No Type of water? Depth of strata Method of sealing strata off

(13) PUMP: Manufacturer's Name Johnston Type: TURBINE H.P. 20

(10) WATER LEVELS: Static level 150 ft. below land surface Date 8/10/62 Artesian pressure lbs. per square inch Date

Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. NAME CHARLES E. HARTLEY (Person, firm or corporation) (Type or print) Address 4779 1/2 S 6TH ST. Drilling Machine Operator's License No. 233 [Signed] Charles E. Hartley (Water Well Contractor) Contractor's License No. 145 Date SEPT 20 1962