KLAM 12377

38/11½-1C

WSB

G-3396

RECEIVED NOV 4 1965 STATE ENGINEER SALEM OREGON

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. ~~38/11½-1BP~~

State Permit No.

(1) OWNER:
Name Karl F. - Isabell M. - Richard K. Dehlinger
Address Klamath Falls, Oregon

(2) LOCATION OF WELL:
County Klamath Driller's well number #one
¼ ¼ Section T. R. W.M.
Bearing and distance from section or subdivision corner
On line between SW¼-SW¼, Sec. 36, T 37S, R11½ EWM, and the NW¼-NW¼ Sec.1, T 38S, R 11½ EWM, being approx. 2500 ft East of the S. W. Corner of Sections 36, T 37S, R11½EWM.

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☒
20" Diam. from 0 ft. to 18 ft. Gage ¼"
16" Diam. from 0 ft. to 460 ft. Gage ¼"
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☒ Yes ☐ No
Type of perforator used Factory Perforation
Size of perforations 3/16 in. by 3 in.
200 perforations from 260 ft. to 460 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed ☐ Yes ☒ No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Conductor Pipe & Bentonite
Depth of seal 18 ft. Was a packer used? no
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? ☐ Yes ☒ No Depth
Was a drive shoe used? ☒ Yes ☐ No
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 87 ft. below land surface Date 9/20/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? Interstate Pump Co.
Yield: gal./min. with ft. drawdown after 4 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 510 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG: Diameter of well below casing
Depth drilled 460 ft. Depth of completed well 460 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Sandy Loam Top Soil	0	3'
Light Brown Clay	3	21'
Green Clay Light Gray Mixed in	21	120'
Green Clay	120	214'
Blue & Green Clay	214	228'
Gray Clay	228	298'
Green Clay (Sticky)	298	317'
Blue Clay	317	327'
Blue Clay & Black Cinders	327	352'
Black Cinders	352	423'
Sandstone	423	426'
Black Cinders	426	460'

Work started 8/17/65 19 . Completed 10/1/65 19
Date well drilling machine moved off of well 10/165 19

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Enloe Drilling Company
(Person, firm or corporation) (Type or print)
Address Susanville, California
Drilling Machine Operator's License No. 342
[Signed] S. J. Enloe
(Water Well Contractor)
Contractor's License No. 57 Date 11/1 19 65

(USE ADDITIONAL SHEETS IF NECESSARY)