

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

**RECEIVED**

CLAM 12085  
385/11 1/2 E-7

STATE OF OREGON  
(Please type or print)

APR 26 1976

State Well No. ....

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

(Do not write above this line)  
WATER RESOURCES DEPT.  
SALEM, OREGON

State Permit No. ....

**(1) OWNER:**

Name Biaggi + Venable G-7396  
Address Dairy Oregon

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

**(4) PROPOSED USE (check):**

Rotary  Driven  Domestic  Industrial  Municipal   
Cable  Jetted  Irrigation  Test Well  Other   
Dug  Bored

**(5) CASING INSTALLED:**

Threaded  Welded

16" Diam. from 0 ft. to 150 ft. Gage 250  
14" Diam. from 145 ft. to 180 ft. Gage 250  
" Diam. from " ft. to " ft. Gage "

**(6) PERFORATIONS:**

Perforated?  Yes  No.

Type of perforator used Factory Saw Cut  
Size of perforations 3/16 in. by 4 in.  
145 perforations from " ft. to " ft.  
980 perforations from 145 ft. to 180 ft.  
perforations from " ft. to " ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
1800 gal./min. with 0 ft. drawdown after 1 hrs.  
2500 " 4 " 4 "

Bailer test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m.  
Temperature of water 53 Depth artesian flow encountered \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**

Well seal—Material used Cement  
Well sealed from land surface to 20 ft.  
Diameter of well bore to bottom of seal 22 in.  
Diameter of well bore below seal 18 in.  
Number of sacks of cement used in well seal 16 sacks  
Number of sacks of bentonite used in well seal \_\_\_\_\_ sacks  
Brand name of bentonite \_\_\_\_\_  
Number of pounds of bentonite per 100 gallons of water \_\_\_\_\_ lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(10) LOCATION OF WELL:**

County Klamath Driller's well number \_\_\_\_\_  
SE 1/4 NE 1/4 Section 7 T. 385 R. 11 1/2 E W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 118 ft.  
Static level 98 ft. below land surface. Date 7-12-75  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

**(12) WELL LOG:**

Diameter of well below casing 14  
Depth drilled 186 ft. Depth of completed well 186 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Sandy Loam	0	10	
Yellow Clay	10	105	
Sandstone	105	118	98
Coarse Cinders & boulders	118	186	
Water bearing			

Work started 7-12 1975 Completed 3-21 1976

Date well drilling machine moved off of well \_\_\_\_\_ 19 \_\_\_\_\_

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] J.C. Ellington Date 3-21, 1976  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 847

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Orrail Buckner  
(Person, firm or corporation) (Type or print)

Address 2586 S.W. 20th Redmond

[Signed] Orrail Buckner  
(Water Well Contractor)

Contractor's License No. 608 Date 4-16 1976