

38/11 1/2 - 33 6/12

WILLIAM L. WALES
CIVIL ENGINEER
KLAMATH FALLS, OREGON

February
Twentieth
1957

RECEIVED
FEB 21 1957
STA. SALEM, OREGON

Office of the State Engineer,
Salem, Oregon.

Attention: Mr. Sceva

Re: Application U-328 - Guy Barton

Gentlemen:

I have filled in, to the best of my ability, the Well Driller's report form enclosed with your letter of February 13th., last. The well was drilled by a man whom I believe has given up the business, and his log doesn't amount to much, but it is the best we have. I am unable to give you the gauge of the short piece of casing but will get it for you as soon as the roads permit me to get to the well.

After the pump was installed, I ran a test on the pump and with the pump discharging 1625 G.P.M. I found the draw-down, measured with my sounding device which can measure well surfaces to an eighth of an inch, to be 1.36 feet, which checks pretty well with the test by the Valley Pump Co.

Trusting these data will be what you desire, I beg to remain,

Yours very truly,

William L. Wales

WLW:sp

Enc.

Copy: Mr. Guy Barton
Route 2, Box 838, Klamath Falls, Oregon.