

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

KLAM 12680 WATER WELL REPORT

KLAM

12680

39/9-21 bc

STATE ENGINEER, SALEM, OREGON 97330 within 30 days from the date of well completion

STATE OF OREGON (Please type or print) (Do not write above this line)

State Well No. State Permit No.

RECEIVED APR 27 1970 STATE ENGINEER SALEM, OREGON

(1) OWNER:

Name Cross Roads Mobile Home Park Address RT 1 Box 925 B Klamath Falls Ore

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [X] Cable [] Dug [] Driven [] Jetted [] Bored []

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal [] Irrigation [] Test Well [] Other []

(11) LOCATION OF WELL:

County Klamath Driller's well number SW 1/4 NW 1/4 Section 21 T. 39S R. 9E W.M. Bearing and distance from section or subdivision corner

(12) WELL LOG:

Diameter of well below casing 6 Depth drilled 215 ft. Depth of completed well 215 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include: TOP SOIL, YELLOW SHALE, GREEN SHALE, GREY SHALE, BLUE SHALE, GREY SHALE WITH STREAKS OF SANDSTONE, GREY SHALE WITH STREAKS OF SAND.

Work started 3/18/70 Completed 3/19/70 Date well drilling machine moved off of well 3/19/70

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] David M. Stoney Date 4/26, 1970 (Drilling Machine Operator)

Drilling Machine Operator's License No. 656

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME E.E. Storey (Person, firm or corporation) (Type or print)

Address 3831 Hope K Falls

[Signed] E.E. Storey (Water Well Contractor)

Contractor's License No. 74 Date 4/26/70, 19

(5) CASING INSTALLED:

6 5/8" Diam. from 71 ft. to 36 1/2 ft. Gage 250

(6) PERFORATIONS:

Perforated? [] Yes [X] No. Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 12 ft. below land surface Date 3/19/70 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [X] No If yes, by whom? Method: gal./min. with ft. drawdown after hrs. AIRLIFT 60 GPM @ 215 1 hr 50 GPM @ 150 1/2 42 GPM @ 105 1/2

(10) CONSTRUCTION:

Well seal—Material used CEMENT Depth of seal 35 ft. Diameter of well bore to bottom of seal 9 7/8 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft.