

RECEIVED KLAM 12857
AUG 28 1961

KLAM
12857

39/10-6M

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

STATE ENGINEER WATER WELL REPORT
SALEM, OREGON STATE OF OREGON 62089

State Well No. _____
State Permit No. _____

(1) OWNER:

Name SKYLINE VIEW DISTRICT IMPROVEMENT CO.
Address C/O EA BEAUDRY 2436 WATSON
KLAMATH FALLS, OREGON

(2) LOCATION OF WELL:

County KLAMATH Owner's number, if any— NONE
NW 1/4 SW 1/4 Section 6 T.395 R. 10E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
10" Diam. from 0 ft. to 260 ft. Gage 189
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used _____
SIZE of perforations in. by in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 250 ft.
Material used in seal— Cement
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off Cement

(10) WATER LEVELS:

Static level 204 ft. below land surface Date July 10, 1956
Artesian pressure NONE lbs. per square inch Date _____

Log Accepted by: _____

[Signed] _____ Date _____, 19____
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level ART REED
Was a pump test made? Yes No If yes, by whom? INTERSTATE PUMP
Yield: 250 gal./min. with 14 ft. drawdown after 4 hrs.
" " " "
" " " "
" " " "
Baller test NONE gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow NONE g.p.m. Date _____
Temperature of water 78 Was a chemical analysts made? Yes No

(12) WELL LOG:

Diameter of well 10 inches.
Depth drilled 630 ft. Depth of completed well 630 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>rock and to soil</u>	<u>0</u>	<u>2</u>
<u>blow sand</u>	<u>6</u>	<u>229</u>
<u>yellow sandstone</u>	<u>229</u>	<u>249</u>
<u>blue chalk</u>	<u>249</u>	<u>368</u>
<u>lava rock</u>	<u>368</u>	<u>630</u>

Work started MARCH 1956 Completed July 7 1956

(13) PUMP:

Manufacturer's Name LAYNE AND BOWLER
Type: DEEP WELL TURBINE H.P. 25

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME W. S. Hartley & Son
(Person, firm, or corporation) (Type or print)
Address Baronza Ore
Driller's well number _____
[Signed] Robert F. Hartley
(Well Driller)
License No. 164 Date July 7, 1956