

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

KLAMATH WATER WELL REPORT

STATE OF OREGON
(Please type or print)

(Do not write above this line)

State Well No. 355/7E-186

State Permit No.

RECEIVED
OCT 15 1976
DEPT.

(1) OWNER:

Name BOB PEPLA
Address 1922 STRADJA RD.
105 SOLEDAD CA. 94029

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded
18" Diam. from 1/12 ft. to 2.00 ft. Gage 2.50
12" Diam. from 1/12 ft. to 4.30 ft. Gage 2.50

PERFORATIONS:

Perforated? Yes No.

Type of perforator used FACTORY
Size of perforations 1/8 in. by 3 in.
perforations from 2.80 ft. to 4.30 ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Type _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? Yes No If yes, by whom? VALLEY PUMP
Yield: 400 gal./min. with 85 ft. drawdown after 24 hrs.

Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.

Artesian flow _____ g.p.m.

Temperature of water 56 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT GRAVEL
Well sealed from land surface to 180 ft.
Diameter of well bore to bottom of seal 26" (cut 20" + 22") in.
Diameter of well bore below seal 18 in.
Number of sacks of cement used in well seal 9 sacks
Number of sacks of bentonite used in well seal NONE sacks
Brand name of bentonite _____

Number of pounds of bentonite per 100 gallons
of water _____ lbs./100 gals.

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.

Did any strata contain unusable water? Yes No

Type of water? _____ depth of strata _____

Method of sealing strata off _____

Was well gravel packed? Yes No Size of gravel: 1/4

Gravel placed from 0 ft. to 4.30 ft.

(10) LOCATION OF WELL:

County KLAMATH Driller's well number #1
N. E. 1/4 NE 1/4 Section 18 T. 35S. R. 7E. W.M.

Bearing and distance from section or subdivision corner SOUTH 47°
WEST 1230 FT. FROM NORTH EAST
1/4 SEC. 18.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 167 ft.
Static level 160 ft. below land surface. Date AUG 16-76
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 12"

Depth drilled 430 ft. Depth of completed well 430 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
SANDY LOAM	0	3	
BROWN SAND	5	15	
GRAVEL	15	32	
BROWN SAND	32	67	
GRAVEL COURSE	67	71	
BROWN SAND	71	90	
GRAVEL COURSE	90	102	
BROWN SAND	102	126	
BROWN CLAY	126	136	
BROWN SAND	136	167	
BLACK SAND	167	183	191
BLUE CLAY	183	381	
COURSE SAND-GRAY	381	384	160
BANK SAND BLACK	384	404	
BLACK SAND COURSE	404	424	
COURSE SAND GRAVEL	424	430	

Work started AUG 20 1975 Completed 8-16 1976
Date well drilling machine moved off of well SEPT 1 1976

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.
[Signed] Charles E. Hartley Date Oct 14 1976
(Drilling Machine Operator)
Drilling Machine Operator's License No. 233

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.
Name CHARLES E. HARTLEY
(Person, firm or corporation)
Address 4779 S. 6TH ST. KLAMATH FALLS
[Signed] Charles E. Hartley
(Water Well Contractor)
Contractor's License No. 145 Date Oct 14 1976