NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

KLAM 12927

KLAM 12927

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

(Do not write above this line)

RECEIVED
AUG 24 1973
STATE ENGINEER
SALEM, OREGON

State Well No. 39S/10E-8

State Permit No.

(1) OWNER:

Name B.H. Donaca

Address 6335 So. Sixth St.
Klamayh Falls Oreg.

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☒

6" Diam. from 0 ft. to 85 ft. Gage 1/4 In.

" Diam. from ft. to ft. Gage

" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test 20 gal./min. with 35 ft. drawdown after 1 hrs.

Artesian flow g.p.m.

Temperature of water 56° Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Bentonite Clay

Well sealed from land surface to 24 ft.

Diameter of well bore to bottom of seal 10 in.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal sacks

Number of sacks of bentonite used in well seal 3 sacks

Brand name of bentonite Aquiel

Number of pounds of bentonite per 100 gallons of water Applied - Dry ~~155/100 gals.~~

Was a drive shoe used? ☒ Yes ☐ No Plugs Size: location ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Klamath Driller's well number

S.E. ¼ N.E. ¼ Section 8 T. 39 S R. 10 E. W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found ft.

Static level 104 ft. below land surface. Date 8-2-73

Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6 In.

Depth drilled 445 ft. Depth of completed well 445 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Brown sandy soil	0	4	
Brown soft sandstone	4	22	
Brown wet running sand	22	76	24
Green claystone	76	255	24
Streaks of fine black sand in blue clay producing approx. 3 g.p.m.			
-------- ----- pppp	255	265	102
Green claystone	265	385	102
Streaks of water producing sand, with a gradual increase of water	385	445	104

Work started 7-2-1973 Completed 8-3 1976

Date well drilling machine moved off of well 8-4 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] James A. Roberts Date 8-23, 1973
(Drilling Machine Operator)

Drilling Machine Operator's License No. 184

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name James A. Roberts Well Drilling
(Person, firm or corporation) (Type or print)

Address 148 East Main St. Klamath Falls, Oreg.

[Signed] James A. Roberts
(Water Well Contractor)

Contractor's License No. 147 Date 8-23, 1973

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119