RECEIVED
JUL 13 1961
STATE ENGINEER
SALEM, OREGON

KLAM 12944

Corr by WRD staff

7 NE NE

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

State Well No. 39/10-8 ~~12~~

State Permit No.

(1) OWNER:
Name Dr. W. F. Dean
Address Klamath Falls, Oregon
6422 Hilyard Ave.

(2) LOCATION OF WELL:
County Klamath Owner's number, if any— 1
NW ¼ NW ¼ Section 8 T. 39 S R. 10 E W.M.
Bearing and distance from section or subdivision corner
900' from NW Corner of NE¼ of Sec 7 thence 90' south

(3) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☐
12¼" Diam. from 0 ft. to 9 ft. Gage 3/16
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☐ Yes ☒ No
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed ☐ Yes ☒ No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? ☒ Yes ☐ No To what depth? 9 ft.
Material used in seal— Portland cement
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 43 b ft. below land surface Date 5/23/61
Artesian pressure lbs. per square inch Date

Log Accepted by:
[Signed] Dr. W. F. Dean (Owner) Date June 3, 1961

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☒ Yes ☐ No If yes, by whom? Interstate Pump Co.
Yield: 340 gal./min. with 23 ft. drawdown after 2 hrs.
" 420 " 36 " 2 "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 72 Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG: Diameter of well 12 inches.
Depth drilled 406 ft. Depth of completed well 406 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
top soil & small boulders	0	3
yellow clay	3	38
gray chalk	38	49
green chalk	49	353
brown chalk & fine sand	353	378
cinders	378	385
broken lava(water bearing)	385	406

Work started 5/9/61 19 . Completed 5/23/61 19

(13) PUMP:
Manufacturer's Name
Type: H.P.

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME John A. Van Meter (Person, firm, or corporation) (Type or print)
Address Box 204 Malin, Oregon
Driller's well number
[Signed] John A. Van Meter (Well Driller)
License No. 170 Date 5/26/61, 19

(USE ADDITIONAL SHEETS IF NECESSARY)