

RECEIVED
JAN 18 1963

KLAM 13033
KLAM

13033

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

STATE ENGINEER WATER WELL REPORT
STATE OF OREGON

State Well No. 39/10-9
State Permit No. _____

(1) OWNER:

Name Donald L. Steers
Address Rt. # 2 Box # 810HA
Klamath Falls Oregon

(2) LOCATION OF WELL:

County Klamath Owner's number, if any—
NE 1/4 NW 1/4 Section 9 T. 39 S R. 10 E W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded

6-5/8" Diam. from 0 ft. to 98 ft. Gage 1/4"
O.D. " Diam. from _____ ft. to _____ ft. Gage _____"

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____

SIZE of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 98 ft.
Material used in seal— Cement & Puddled clay
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 128 ft. below land surface Date 1-5-63
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by: _____

[Signed] _____ Date _____, 19____
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
" " " " "
Bailer test 14 gal./min. with 60 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 54 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 6 inches.

Depth drilled 976 ft. Depth of completed well 976 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Brown sandy soil	0	2'
Yellow Claystone	2'	39'
Green Claystone	39'	142'
Streaks of black sand in green claystone		
water bearing approx. 1 1/2 G.P.M.	142'	150'
Green claystone	150'	435'
Grey claystone	435'	453'
Green claystone	453'	692'
Grey claystone	692'	734'
Green claystone	734'	770'
Grey claystone	770'	782'
Green claystone	782'	835'
Grey claystone	835'	875'
Green claystone with very fine black sand in streaks & gradual increase of water.	875'	976'
Machine operators license # 184		
Moved Drilling machine off well site 1-5-63		

Work started 11-20-62 19____ Completed 1-5-63 19____

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME James A. Roberts
(Person, firm, or corporation) (Type or print)
Address 148 East Main St. Klamath Falls Ore.
Driller's well number _____
[Signed] James A. Roberts
(Well Driller)
License No. 147 Date 1-16-63, 19____