NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

KUAM	State	Well No. 35s/7E-	28 dd
1343	State	Permit No	

(1) OWNER:	(10) LOCATION OF WELL:		
Name James Rogers	County Klamath Driller's well number		
Address Star Rt. Box 13	SE 14 SE 14 Section 28 T.35 S R. 7 E W.M.		
Chiloquin, Oregon 97624	Bearing and distance from section or subdivision of	corner	
(2) TYPE OF WORK (check):			
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed well.		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found	4	ft.
Rotary Driven Domestic M Industrial Municipal D	Static level 12 ft. below land surfa	ace. Date 5-	-2-80
Grade Jetted Irrigation Test Well Other	Artesian pressure lbs. per square in		
(5) CASING INSTALLED: Threaded Welded W Welded M Gage 250	(12) WELL LOG: Diameter of well below		6"
ft. Gage	Depth drilled 73 ft. Depth of completed		73 ft.
" Diam. from ft. to ft. Gage	Formation: Describe color, texture, grain size and and show thickness and nature of each stratum a		
(6) PERFORATIONS: Perforated? ▼ Yes ★★★★★6.	with at least one entry for each change of formation. position of Static Water Level and indicate principa	. Report each c	hange in
Type of perforator used P.V.C.			SWL
1/0		0 4	
Size of perforations 1/8 in. by 6 in. 45 perforations from33 ft. to73 ft.	Top Soil Gravel	4 6	12'
	Brown Clay	6 18	14_
perforations from	Sand & Gravel	18 27	
perforations from ft. to ft.	Sandstone	27 35	12'
(7) SCREENS: Well screen installed? ☐ Yes ☒ No	Sandstone & Gravel	35 73	12'
Manufacturer's Name			
Type Model No			
Diam. Slot size Set from ft. to ft.			
Diam. Slot size Set from ft. to ft.			
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	DECENTED		
We a pump test made? ☐ Yes ☐ No If yes, by whom? Driller	- 1071; 2 7 1990		
Neld: 30 gal./min. with 60 ft. drawdown after 1 hrs.	WATER RESOURCES DEPT		
<i>n n n</i>	SALEM, OREGON		
" " " "	Cr.Lim, OREGOIN		
Bailer test gal./min. with ft. drawdown after hrs.			
sian flow g.p.m.			
Temperature of water 58 Depth artesian flow encountered ft.	Work started 5-2 19 80 Completed	5-2	1980
(9) CONSTRUCTION:	Date well drilling machine moved off of well	5-2	1980
Well seal-Material used Cement-1 Sack Bentonite	Drilling Machine Operator's Certification:		
Well sealed from land surface toft.	This well was constructed under my din Materials used and information reported abo	rect superv	ision.
Diameter of well bore to bottom of seal in. in.	best knowledge and belief.	ove are true	to my
Diameter of well bore below sealin.	[Signed] flory & Marfurd Bat	e5-5,	1980
Number of sacks of cement used in well seal 10 sacks	(Drilling Machine Operator)	1388	
How was cement grout placed? Pumped from bottom of casing up to the ground surface.	Drilling Machine Operator's License No	1,000	
	Water Well Contractor's Certification:		
Was a later to the state of the	This well was drilled under my jurisdictio true to the best of my knowledge and belief.	m and this re	port is
Was a drive shoe used? M Yes □ No Plugs Size: location ft. Did any strata contain unusable water? M Yes □ No	Name Norm Sevey Well Drilling, Inc. (Person, firm or corporation) (Type or print)		
Type of water? Surface depth of strata 4' to 6'	Address 5619 Leland Dr. Klamath F	-	
Method of sealing strata off Casing & Cement	[Signed] Ham Sive		
Was well gravel packed? ☐ Yes 🛮 No - Size of gravel:	(Water Well Contractor		00
Gravel placed from ft. to ft.	Contractor's License No. 408 Date		<u>, 1900</u>