

KLAM 13472

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion

STATE OF OREGON

(Please type or print) (Do not write above this line)

State Well No. 39/11 1/2 - 13 J

State Permit No.

RECEIVED MAY 29 1968

G-4832

(1) OWNER: STATE ENGINEER

Name VIRGIL SCHMACKERLON Address DAIRY, ORE.

(11) LOCATION OF WELL:

County KLAMATH Driller's well number NE 1/4 SE 1/4 Section 13 T. 39S R. 11 1/2 E W.M. Bearing and distance from section or subdivision corner

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [X] Driven [] Cable [] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

(12) WELL LOG:

Diameter of well below casing .15 Depth drilled 395 ft. Depth of completed well 395 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

Table with columns: MATERIAL, From, To, SWL. Rows include: TOP SOIL (0-3), SAND + CLAY (3-12), YELLOW CLAY (12-18), GREEN SHALE WITH STREAKS OF SANDSTONE (18-365), BROWN OR RED LAVAS OF TYPE BROKEN BLACK LAVA (365-390).

(6) CASING INSTALLED:

Threaded [] Welded [X] 16" Diam. from +1 ft. to 38 ft. Gage 250

PERFORATIONS:

Perforated? [] Yes [X] No. Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Type Model No. Diam. Slot size Set from ft. to ft.

(8) WATER LEVEL: Completed well.

Static level 20 ft. below land surface Date 5/6/68 Artesian pressure lbs. per square inch Date

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [X] Yes [] No If yes, by whom? PUMP CENTER 1900 gal./min. with 10.3 ft. drawdown after 6 hrs.

Work started 4/29/68 19 Completed 5/6/68 19 Date well drilling machine moved off of well 5/6/68 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] E. E. Stacey Date 5/10/68, 19 (Drilling Machine Operator)

Drilling Machine Operator's License No. 115

(10) CONSTRUCTION:

Well seal—Material used BENTONITE Depth of seal 37 ft. Diameter of well bore to bottom of seal 20 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME E. E. Stacey (Person, firm or corporation) (Type or print)

Address 3831 Hope K. FALLS

[Signed] E. E. Stacey (Water Well Contractor)

Contractor's License No. 74 Date 5/10/68, 19