

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

RECEIVED KLAM
STATE OF OREGON
(See type on form)
13534
AUG 9 1978
(Do not write on this line)

State Well No. 395/12E+0b1
State Permit No.

(1) OWNER:

Name TOWN OF BONANZA
Address BONANZA ORE ZIP 97623

WATER RESOURCES DEPT. LOCATION OF WELL:

County Klamath Driller's well number
NW 1/4 NW 1/4 Section 10 T. 39S R. 12E W.M.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dug
Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

0" Diam. from 0 ft. to 38 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
AIR TEST 60 G.P.M. @ "125' ONE HR."
Ball test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 59 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 38 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 13 sacks
How was cement grout placed? PUMPED IN

Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? SURFACE depth of strata 6'
Method of sealing strata off CEMENT
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 90 ft.
Static level 11 ft. below land surface. Date 8-6-78
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"
Depth drilled 125 ft. Depth of completed well 125 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Med. Sand Brown	0	6	
Clay Brown	6	20	
Clay Gray	20	90	
Sand Stone clay Block	90	125	
Water found in Sand Stone Layers			

Work started 8-3-1978 Completed 8-6-1978
Date well drilling machine moved off of well 8-7-1978

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Russ Hartley Date 8-7-1978
(Drilling Machine Operator)
Drilling Machine Operator's License No. 1095

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name CHARLES HARTLEY WELL DRILLING
(Person, firm or corporation) (Type for print)
Address 4779 S. 6th Klamath Falls, OR
[Signed] Charles Hartley
(Water Well Contractor)
Contractor's License No. 145 Date 8-7-1978