

NOTICE TO WATER WELL CONTRACTOR: The original and first copy of this report are to be filed with the

RECEIVED

KLAM 13578 WATER WELL REPORT

KLAM 135.78

#6 39S/12E-31ad

WATER RESOURCES DEPARTMENT SALEM, OREGON 97310 within 30 days from the date of well completion

OCT 31 1978

STATE OF OREGON (Please type or print)

State Well No.

State Permit No.

SALEM, OREGON

(Do not write above this line)

Cancelled by SE NE

(1) OWNER:

Name Mr & Mrs Robert Horton

Address 1940 Painter Street

Klamath Falls, Oregon

(2) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [X] Driven [] Cable [] Jetted [] Dug [] Bored []

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [X] Test Well [] Other []

CASING INSTALLED:

Threaded [] Welded [X] 250

PERFORATIONS:

Perforated? [] Yes [X] No.

Type of perforator used

Size of perforations in. by in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [X] Yes [] No If yes, by whom? Art Reed

Yield: gal./min. with ft. drawdown after hrs.

'Attached' " " "

" " " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water 70 Depth artesian flow encountered 110 ft.

(9) CONSTRUCTION:

Well seal—Material used Cement

Well sealed from land surface to 20 ft.

Diameter of well bore to bottom of seal 18 in.

Diameter of well bore below seal 12 in.

Number of sacks of cement used in well seal 15 sacks

How was cement grout placed? Poured in.

Was a drive shoe used? [] Yes [X] No Plugs Size: location ft.

Did any strata contain unusable water? [] Yes [X] No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? [] Yes [X] No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Klamath Driller's well number

SE 1/4 Se 1/4 Section 31 T. 39S R. 12E W.M.

Bearing and distance from section or subdivision corner

Approx 100X feet west and 100 feet

north of the SE corner of S 31 T 39S R 12E

(11) WATER LEVEL: Completed well.

Depth at which water was first found 110 ft.

Static level 0 ft. below land surface. Date

Artesian pressure 2 lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 12

Depth drilled 292 ft. Depth of completed well 292 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

Table with columns: MATERIAL, From, To, SWL. Rows include Top Soil, Yellow Clay, Brown sticky clay, Yellow clay, Grey clay, Lava Brown broken, Red lava broken, Blue grey broken lava, Grey clay.

Work started 4-10 1977 Completed 4-20-1978

Date well drilling machine moved off of well 4-21-1978

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Walter F. Wilson Date 4-30-1978 (Drilling Machine Operator)

Drilling Machine Operator's License No. 201

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Wilson Drilling Contractor Inc. (Person, firm or corporation) (Type or print)

Address P.O. Box 136, Merrill, Oregon

[Signed] Walter F. Wilson (Water Well Contractor)

Contractor's License No. 169 Date 4-30, 1978

KLAM 13578
WATER WELL TEST REPORT
CAPACITY & DRAW-DOWN

Klam 13578

CUSTOMER: INDIAN HILLS RANCH
ROBERT I HORTON
GRETA M HORTON

DATE 4-30-77

LOCATION OF WELL: SE COR. SE 1/4 SE 1/4 SEC 31 TWP 39 S.
R. 12 E W M.

WELL DATA: _____

EQUIPMENT USED FOR TEST: 4-stage 1 1/2" Bore, 80' x 6"
Column, Buba Diesel Power Units Various speeds.

STATIC LEVEL AT START. 0' TIME STARTED 9:00 AM

G.P.M.	PUMPING LEVEL	DRAW*DOWN	TIME	COMMENTS.
1800	47'	47'	1-hr.	GREAT
1400	30'	30'	2-hr.	-
1800	47'	47'	3-hr.	-
1950	57'	57'	4-hr.	-
1950	57'	57'	5-hr.	-

RECEIVED
OCT 31 1978
WATER RESOURCES DEPT.
SALEM, OREGON

TEMP. 72° STATIC LEVEL AFTER TEST COMPLETED 0'

COMMENTS: Strong Recovery.
Very good well

TEST PUMP OPERATORS CERTIFICATION: This well was tested under my jurisdiction and this report is true to the best of my knowledge and belief.

Signed: Art Reed
Address: 7335 Homedale Rd
Klamath Falls, Ore. 97601

Witnessed by: _____