

KLAM
13601

KLAM 13601

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM 10, OREGON
within 30 days from the date
of well completion.

*Mark
No. 3*

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

SEP 18 1963

State Well No. 39/13E-1
State Permit No. _____

(1) OWNER:
Name Bureau of Land Management
Address Lakeview, Oregon

(2) LOCATION OF WELL:
County Klamath Driller's well number _____
1/4 Section 1412, T. 39S, R. 13E W.M.
Bearing and distance from section or subdivision corner _____

(3) TYPE OF WORK (check):
Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Cable Dug
Driven Jetted Bored

(6) CASING INSTALLED:
Threaded Welded
" Diam. from 0 ft. to 11 1/2 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:
Perforated? Yes No
Type of perforator used _____
Size of perforations in. by _____ in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:
Well screen installed Yes No
Manufacturer's Name _____
Model No. _____
Diam. Slot size _____ Set from _____ ft. to _____ ft.
Diam. Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Clay & Cement
Depth of seal 20 ft. Was a packer used? No
Diameter of well bore to bottom of seal 12 1/2 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 360 ft. below land surface Date 8/22/63
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: 6 gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" Air-Blow " " " " "
Bailer test 6 gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 8"
Depth drilled 442 ft. Depth of completed well 442 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>Top soil & boulders</u>	<u>0</u>	<u>2</u>
<u>Lava rock</u>	<u>2</u>	<u>21</u>
<u>Clay & gravel</u>	<u>21</u>	<u>30</u>
<u>Lava rock</u>	<u>30</u>	<u>41</u>
<u>Clay & gravel - orange</u>	<u>41</u>	<u>50</u>
<u>Lava rock - gray</u>	<u>50</u>	<u>90</u>
<u>Lava rock - dark gray</u>	<u>90</u>	<u>140</u>
<u>Clay stone</u>	<u>140</u>	<u>160</u>
<u>Lava rock gray</u>	<u>160</u>	<u>246</u>
<u>Clay stone - hard</u>	<u>246</u>	<u>264</u>
<u>Lava rock -</u>	<u>264</u>	<u>352</u>
<u>Some - water 2 A.P.M.</u>	<u>352</u>	<u>352</u>
<u>Lava rock</u>	<u>352</u>	<u>370</u>
<u>Clay stone - hard</u>	<u>370</u>	<u>408</u>
<u>Lava rock</u>	<u>408</u>	<u>442</u>
<u>water at 416 - 4 G.P.M.</u>		

Work started 8/12/63 Completed 8/22/63
Date well drilling machine moved off of well 8/22/63

(13) PUMP:
Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME W.E. Majors Drilling Co
(Person, firm or corporation) (Type or print)
Address P.O. Box 327 Central Point, Ore
Drilling Machine Operator's License No. 5
[Signed] W.E. Majors
(Water Well Contractor)
Contractor's License No. 326 Date 8/22/63