

ORIGINAL
File Original and
Duplicate with the
STATE ENGINEER,
SALEM, OREGON

KLAM
13654

WATER WELL DRILLERS REPORT

RECEIVED
JUL 30 1956

Do Not State Well No. 407-1
Fill In State Permit No.

(1) OWNER:

Name F.W. Borges STATE ENGINEER
Address P.O. Box 25 SALEM, OREGON
Keno, Oregon

(2) LOCATION OF WELL:

County Klamath Owner's number, if any--
R. F. D. or Street No.
Bearing and distance from section or subdivision corner
Sec. 1, T. 40 S, R 7 E W.M.

(10) WELL TESTS:

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. draw down after hrs.
Artesian flow g.p.m.
Shut-in pressure lbs. per square inch.
Bailer test 20 g.p.m. with held ft. drawdown
Temperature of water 42 Was a chemical analysis made? Yes No
Was electric log made of well? Yes No

(3) TYPE OF WORK (check):

well # Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic # Industrial Municipal
Irrigation Test Well Other

(5) EQUIPMENT:

Rotary
Cable
Dug Well

CASING INSTALLED:

Table with columns: FROM, ft. to, ft., Diam., Gage or Wall. Row 1: X 2 65 1/2 8 5/8 .188

If gravel packed

Type and size of shoe or well ring Couplings Size of gravel:
Describe joint Grout

(11) WELL LOG:

Diameter of well, 8 inches.
Total depth 293 ft. Depth of completed well 293 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.
0 ft. to 6 ft. top soil
6 " 10 " Boulders & clay
10 " 28 " Red clay
28 " 38 " Boulders
38 " 45 " Clay red
45 " 52 " Brown rock hard
52 " 63 " Cinders & red clay
63 " 75 " Grey rock
75 " 82 " Cinders & brown clay
82 " 202 " Crevices rock
202 " 207 " Loose boulders- cemented
207 " 275 " Grey rock
275 " 290 " small boulders water flow
290 " 293 " Black rock hard

(7) PERFORATIONS:

Table with columns: SIZE of perforations, in., length, by, in. Includes rows for DM, ft. to, ft., perf per foot, No. of rows.

SCREENS:

Give Manufacturer's Name, Model No. and Size

(8) CONSTRUCTION:

Was a surface sanitary seal provided? Yes No To what depth 65 1/2 ft.
Were any strata sealed against pollution? Yes No
If yes, note depth of strata
FROM ft. to ft.
METHOD OF SEALING

(9) WATER LEVELS:

Depth at which water was first found 275 ft.
Standing level before perforating 269 1/2 ft.
Standing level after perforating ft.
Log Accepted by:
[Signed] Frank W. Borges Dated July 27, 1956
Owner

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME E. E. Storey welldrilling (Person, firm, or corporation) (Typed or printed)
Address 4237 Summers Ln. Klamath Falls, Ore.
Driller's well number
[Signed] E. E. Storey (Well Driller)
License No. 74 Dated 7/7, 1956.