

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

WATER WELL REPORT

RECEIVED
STATE OF OREGON
MAY 1 1973
STATE ENGINEER
SALEM, OREGON

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

(Please type or print)
State Well No. 405/8E-6
State Permit No. _____
(Do not write above this line)

N.C.
Klamath
13722

(1) OWNER:

Name Klamath River Acres
Address PO Box 52
Keno, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
8" Diam. from ±1 ft. to 19 ft. Gage 1250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____
Size of perforations in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
_____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "
Pump test 130 gal./min. with 274 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m.
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used Nect Cement
Well sealed from land surface to 19 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 8 in.
Number of sacks of cement used in well seal 8 sacks
Number of sacks of bentonite used in well seal _____ sacks
Brand name of bentonite _____
Number of pounds of bentonite per 100 gallons of water _____ lbs./100 gals.
Was a drive shoe used? Yes No Plug _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Klamath Driller's well number _____
1/4 Section 6 T. 40 R. 8E W.M.

Bearing and distance from section or subdivision corner 45' south
220' east from the NW property
corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 197 ft.
Static level 27 ft. below land surface. Date 4-17-73
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 8

Depth drilled 300 ft. Depth of completed well 300 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
soil - sandy - brown	0	9	
Clay - brown	9	11	
basalt - blue grey	11	197	
basalt - seams	197	235	27
basalt - blue grey	235	267	
basalt - seams	267	291	27
basalt - blue grey	291	300	

Work started 4-17 1973 Completed 4-17 1973
Date well drilling machine moved off of well 4-17 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Charles D. Chittenden Date 4-25, 1973
(Drilling Machine Operator)

Drilling Machine Operator's License No. 344

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Crater Well Drilling Inc.
(Person, firm or corporation) (Type or print)

Address 1923 Delta Waters Rd Madras

[Signed] Charles D. Chittenden
(Water Well Contractor)

Contractor's License No. 545 Date 4-25, 1973