RECEIVED

JUL1 7 1984

KLAM 13848

STATE OF OREGON WATER WELL REPORT (as required by ORS 537.765)

WATER DESPURCES IDENTINK
SALEM, OREGON

395/7E-25da	
	-

(for official use only)

(1) OWNER:	(10) LOCATION OF WELL by legal description:		
Name Delbert Sparks	County Klamath NE 1/4 SE 1/4 of Section 25 of		
Address 8314 Mc Laughlin Ln.	Township 39 South Range 7 East , WM.		
City Klamath Falls, State OR. 97601		tange is East of West) <u>lamath River Ace</u> rs	
(2) TYPE OF WORK (check):	MAILINC ADDRESS OF WELL (or nearest address)		
New Well 🗵 Deepening 🗆 Reconditioning 🗆 Abandon 🗖	8818 Ben Kerns Rd. Klamath Falls, OR. 97601		
If abandonment, describe material and procedure in Item 12.			
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL of COMPLET	ED WELL:	
Rotary Air XX Driven Domestic X Industrial Municipal	Depth at which water was first found 88	ft.	
Rotary Mud Dug Irrigation Withdrawal Reinjection	•	and surface. Date 6, 22, 84	
Cable Bored Dotter: Piezometric Grounding Test	Artesian pressure lbs. per	square inch. Date	
(5) CASING INSTALLED: Steel Harmon Plastic Welded Harmon On ft. to 47 ft. Gauge 250 LINER INSTALLED: Steel Plastic Plastic Harmon Plastic Pla		ast one entry for each change of	
LINER INSTALLED: Steel Plastic Welded Welded	MATERIAL	From To SWL	
"Diam. fromft. toft. Gauge	Brown clay & boulders	0 33	
(6) PERFORATIONS: Perforated? Yes No	Black lava rock	33 50	
Size of perforations in. by in.	Brown lava rock & clay	50 71	
perforations from	Black lava rock	71 80	
perforations from ft. to	Brown lava rock & clay Black lava rock	80 88 88 106 70 '	
perforations from	Brown lava rock	106 128 70'	
(7) SCREENS: Well screen installed? ☐ Yes ☐ No	Red lava rock	128 131 70	
Manufacturer's Namenone	Black lava rock	131 152 70	
Type	Black rock (hard)	152 159	
Diam Slot Size Set from ft. to ft.			
Diam Slot Size Set from ft. to ft.	. 90.		
(8) WELL TESTS: Drawdown is amount water level is lowered below static level			
Was a pump test made? ☐ Yes ☐ No If yes, by whom? driller			
d: gal/min. with ft. drawdown after hrs.			
Air test 60 gal./min. with drill stem at 158 ft. 1 hrs.			
Baldrest 45 gal/minfrom 138ft, drawdown after 1 hrs.			
Artesian flow g.p.m.			
perature of water 58 Depth artesian flow encounteredft.	Date work started 6 21 814 /completed	1 (00 0)	
(9) CONSTRUCTION: Special standards: Yes 🗆 No 🔀			
Well seal—Material usedcement and bentonite			
Well sealed from land surface to	(unbonded) Water Well Constructor Certification (if applicable): This well was constructed under my direct supervision. Materials used and		
Diameter of well bore to bottom of seal	information reported above are true to my best knowledge and belief.		
Amount of sealing material	[Signed]		
How was cement grout placed?Pumped_from_bottom_of			
seal up to the ground surface.	(bonded) water well Constructor Certification:		
	Bond 208 211 34 Issued by: Western Surety Co. (Surety Company Name)		
Was pump installed? Type HP Depth ft.	On behalf of Norm Sevey Well Drilling, Inc.		
Was a drive shoe used? ☐ Yes ☒ No Plugs			
Type of Water? none depth of strata	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief:		
Method of sealing strata off	41 1		
Was well gravel packed? Yes No Size of gravel:	(Water Well Constructor)		
Gravel placed fromft. toft.	(Dated)July, 16th, 1984	***************************************	
	<u> </u>		