

RECEIVED  
MAR 7 1961

APR 11 1961 FUNDS MAILED

14118 KLAM 39/8-6

WATER WELL REPORT

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

STATE ENGINEER

STATE OF OREGON

State Well No. ....

State Permit No. ....

(1) OWNER:

Name W R OWENS  
Address 1022 JEFFERSON ST  
Red BLUFF, CALIF

(2) LOCATION OF WELL:

County KLAMATH Owner's number, if any— 2  
Bearing and distance from section or subdivision corner  
Section 6, approx 600 ft South of middle corner of L. O. Brass Cap

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(5) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

(6) CASING INSTALLED:

Threaded  Welded   
" Diam. from ..... ft. to ..... ft. Gage .....  
1.8 " Diam. from +1 ft. to 1.8 ft. Gage 1/4

(7) PERFORATIONS:

Perforated?  Yes  No  
Type of perforator used  
SIZE of perforations in. by in.  
perforations from ..... ft. to ..... ft.  
perforations from ..... ft. to ..... ft.  
perforations from ..... ft. to ..... ft.  
perforations from ..... ft. to ..... ft.

(8) SCREENS:

Well screen installed  Yes  No  
Manufacturer's Name .....  
Type ..... Model No. ....  
Slot size ..... Set from ..... ft. to ..... ft.  
Slot size ..... Set from ..... ft. to ..... ft.

(9) CONSTRUCTION:

Was well gravel packed?  Yes  No Size of gravel: .....  
Gravel placed from ..... ft. to ..... ft.  
Was a surface seal provided?  Yes  No To what depth? 18 ft.  
Material used in seal— CEMENT  
Did any strata contain unusable water?  Yes  No  
Type of water? ..... Depth of strata .....  
Method of sealing strata off .....

(10) WATER LEVELS:

Static level 130 ft. below land surface Date 1/25/61  
Artesian pressure ..... lbs. per square inch Date .....

Log Accepted by .....  
[Signed] William R. Owens Date 1/9, 1961  
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom? Valley Pump  
Yield: gal./min. with ft. drawdown after hrs.  
" 2000 " 24 " 4 "  
" " " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m. Date  
Temperature of water 58 Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well 16 inches.  
Depth drilled 360 ft. Depth of completed well 360 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	10
BOULDERS	10	59
BROWN SILT	59	64
BOULDERS	64	80
POROUS BROWN LAVA	80	100
BROWN LAVA	100	120
GRAY BASALT	120	131
BROKEN BROWN LAVA N.F.	131	135
BROWN LAVA	135	208
GRAY BASALT	208	214
BROWN LAVA	214	230
GRAY BASALT	230	251
BROWN LAVA	251	268
GRAY BASALT	268	280
BROWN LAVA	280	286
GRAY BASALT	286	291
BROWN LAVA	291	304
GRAY BASALT	304	312
BLACK BASALT	312	317
GRAY BASALT	317	348
DARK GRAY BASALT W.F.	348	356
GRAY BASALT	356	360

Work started 11/4 1960 Completed 1/27 1961

(13) PUMP:

Manufacturer's Name .....  
Type: ..... H.P. ....

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME E.E. STOREY  
(Person, firm, or corporation) (Type or print)

Address 4237 SUMMERS LN, K. FALLS, ORE

Driller's well number .....

[Signed] BB Storey  
(Well Driller)

License No. 74 Date 1/27, 1961