

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

(Do not write above this line)

RECEIVED
Klamath
12128
State Well No. 395/8E-7CC
JAN 7 1980
State Permit No.

WATER RESOURCES DEPT
SALEM, OREGON

(1) OWNER:

Name Gary Hutchenson
Address Rt. 3 Box 312
Klamath Falls, Oregon 97601

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

(4) PROPOSED USE (check):

Rotary Driven
Cable Jetted
Dug Bored
Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
6" Diam. from 0 ft. to 40 ft. Gage .250
" Diam. from " ft. to " ft. Gage "
" Diam. from " ft. to " ft. Gage "

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used

Size of perforations in. by in.
perforations from " ft. to " ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Type _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? driller
2 Field: 25 gal./min. with 28 ft. drawdown after 1 hrs.
" " " " "
" " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 68 Depth artesian flow encountered " ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
Well sealed from land surface to 38 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal " in.
Number of sacks of cement used in well seal 11 sacks
How was cement grout placed? Pumped from the bottom of the seal up to the ground surface

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from " ft. to " ft.

(10) LOCATION OF WELL:

County Klamath Driller's well number _____
SW 1/4 SW 1/4 Section 7 T.39 S R. 8 E. W.M.
Bearing and distance from section or subdivision corner _____
Tax Lot 2211

(11) WATER LEVEL: Completed well.

Depth at which water was first found 195 ft.
Static level 144 ft. below land surface. Date 12, 17, 79
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6 inch.

Depth drilled 212 ft. Depth of completed well 212 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Boulders	0	2	
Black rock	2	13	
Brown lava rock	13	22	
Black rock	22	30	
Brown lava	30	35	
Black rock	35	67	
Claystone	67	75	
Black rock	75	107	
Brown claystone	107	130	
Lava rock	130	148	
Black rock	148	195	
Broken rock	195	212	144'

Work started 12, 11, 19 79 Completed 12, 17, 1979
Date well drilling machine moved off of well 12, 17, 1979

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief

[Signed] *George L. Maxwell* Date 12, 18, 1979
(Drilling Machine Operator)

Drilling Machine Operator's License No. 1388

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Norm Sevey Well Drilling, Inc.
(Person, firm or corporation) (Type or print)

Address 5619 Leland Dr. Klamath Falls, Ore. 97601

[Signed] *Norm Sevey*
(Water Well Contractor)

Contractor's License No. 408 Date 12, 18, 1979