

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL CONTRACTOR

STATE OF OREGON
(Please type or print)

(Do not write above this line)

RECEIVED

MAR 7 1983

State Well No.

State Permit No.

Corrected by WRD staff

395/8E-2166

39S 8E 12 SWNW

SALEM, OREGON

(1) OWNER:

Name Don KUC REA
Address RT 1 BOX 856
KLAMATH FALLS OR 97601

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

12" Diam. from 2 ft. to 56 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

IR TEST APPROX 1000 RPM FROM 380
VALVE PUMP IS TOO TEST WELL

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water 68° Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT

Well sealed from land surface to 54 ft.

Diameter of well bore to bottom of seal 16 in.

Diameter of well bore below seal 12 in.

Number of sacks of cement used in well seal 17 sacks

How was cement grout placed?
PUMPE IN BY 1" PIPE
& DIAPHRAM PUMP TO TOP

Was a drive shoe used? Yes No Plugs Size: location ft.

Did any strata contain unusable water? Yes No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? Yes No Size of gravel:

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County KLAMATH Driller's well number
N.W. 1/4 NW 1/4 Section 21 T. 39S. R. 8E. W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 192 ft.

Static level 57 ft. below land surface. Date 2-20-83

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 12"

Depth drilled 415 ft. Depth of completed well 415 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL HEAVY	0	4	
COARSE LOOS ROCK DEFS.	4	6	
CHAULK	6	38	
BLUE CLAY	38	79	
GREEN SHALE	79	130	
BLACK HARD SHALE	130	167	
BLACK SANDSTONE	167	192	W.B.
BLACK ROCK	192	201	W.B.
BLACK ROCK + SANDSTONE	201	292	W.B.
HARD BLUE LAVA ROCK	292	315	
HARD BROKEN ROCK	315	317	W.B.
HARD BLUE LAVA ROCK	317	330	
HARD BROKEN ROCK	330	335	W.B.
HARD BLUE LAVA ROCK	335	400	W.B.
BROKEN LAVA ROCK	400	415	
VERY GOOD LAVA FIRE			
4 WATER BARRIER			

Work started 2-9 1983 Completed 2-21 1983

Date well drilling machine moved off of well 2-21 1983

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Charles E. Hartley Date 3-3, 1983
(Drilling Machine Operator)

Drilling Machine Operator's License No. 233

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name CHARLES E. HARTLEY
(Person, firm or corporation) (Type or print)

Address 779 5th Klamath Falls OR

[Signed] Charles E. Hartley
(Water Well Contractor)

Contractor's License No. 145 Date 3-3, 1983