

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT
SALEM, OREGON 97310
within 30 days from the date of well completion.

WATER WELL RECEIVED
KLANAM 14254

STATE OF OREGON
(Please type or print)
MAY 7 1983

State Well No. 395/8E-2166
Permit No.

WATER RESOURCES DEPT
SALEM, OREGON

(1) OWNER:

Name Don KUC REA
Address RT 1 BOX 856
KLAMATH FALLS OR 97601

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dug
Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

12" Diam. from 2 ft. to 56 ft. Gage 250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
IR TEST APPROX 1000 P.M. FROM 300
VALVE PUMP IS "100 TEST WELL"
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 68° Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT
Well sealed from land surface to 54 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 17 sacks
How was cement grout placed?
PUMPED IN BY 1" PIPE
+ DIAPHRAM PUMP TO TOP
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County KLAMATH Driller's well number
N.W. 1/4 NW 1/4 Section 21 T. 39S. R. 8E. W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 192 ft.
Static level 57 ft. below land surface. Date 2-20-83
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 12"
Depth drilled 415 ft. Depth of completed well 415 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL HEAVY	0	4	
COARSE LOOS BOUNDED BS.	4	6	
CHALK	6	38	
BLUE CLAY	38	79	
GREEN SHALE	79	130	
BLACK HARD SHALE	130	167	
BLACK SANDSTONE	167	192	W.B.
BLACK ROCK	192	301	W.B.
BLACK ROCK + SANDSTONE	301	392	W.B.
HARD BLUE LAVA ROCK	392	315	
HARD BROKEN ROCK	315	317	W.B.
HARD BLUE LAVA ROCK	317	330	
HARD BROKEN ROCK	330	335	W.B.
HARD BLUE LAVA ROCK	335	400	W.B.
BROKEN LAVA ROCK	400	415	
VERY GOOD AQUA FERE			
4 WATER BARRIER			

Work started 2-9 1983 Completed 2-21 1983
Date well drilling machine moved off of well 2-21 1983

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Charles E. Hapley Date 3-3, 1983
(Drilling Machine Operator)
Drilling Machine Operator's License No. 253

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name CHARLES E. HAPLEY
(Person, firm or corporation) (Type or print)
Address 1779 S. KLAMATH FALLS O.R.
[Signed] Charles E. Hapley
(Water Well Contractor)
Contractor's License No. 145 Date 3-3, 1983