

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

# WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

State Well No. 405/9E-5

State Permit No. \_\_\_\_\_

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

*Klamath*  
*14512*

### (1) OWNER:

Name Frank Kuonen  
Address Rt. 1 Box 894-A  
Klamath Falls, Oregon 97601

### (2) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon

If abandonment, describe material and procedure in Item 12.

### (3) TYPE OF WELL:

Rotary  Driven   
Cable  Jetted   
Dug  Bored

### (4) PROPOSED USE (check):

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

### CASING INSTALLED:

Threaded  Welded   
6" Diam. from 0 ft. to 144 ft. Gage 250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

### PERFORATIONS:

Perforated?  Yes  No.

Type of perforator used \_\_\_\_\_  
Size of perforations in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

### (7) SCREENS:

Well screen installed?  Yes  No

Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

### (8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
" " " " " "  
" " " " " "  
Bailer test 30 gal./min. with 98 ft. drawdown after 1 hrs.  
Artesian flow \_\_\_\_\_ g.p.m.

Temperature of water 70 Depth artesian flow encountered \_\_\_\_\_ ft.

### (9) CONSTRUCTION:

Well seal—Material used Cement  
Well sealed from land surface to 144 ft.  
Diameter of well bore to bottom of seal 10 in.  
Diameter of well bore below seal 6 in.  
Number of sacks of cement used in well seal 18 sacks  
Number of sacks of bentonite used in well seal none sacks  
Brand name of bentonite \_\_\_\_\_  
Number of pounds of bentonite per 100 gallons \_\_\_\_\_  
of water \_\_\_\_\_ lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs \_\_\_\_\_ Size: location \_\_\_\_\_ ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? hard, 40gr. depth of strata 125'  
Method of sealing strata ca casing and cement  
Was well gravel packed?  Yes  No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

### (10) LOCATION OF WELL:

County Klamath Driller's well number \_\_\_\_\_  
NE 1/4 SE 1/4 Section 5 T. 40 R. 9 E W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

### (11) WATER LEVEL: Completed well.

Depth at which water was first found 270 ft.  
Static level 22 ft. below land surface. Date 12, 17, 75  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_

### (12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 620 ft. Depth of completed well 620 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Hard clay	0	4	
Brown clay	4	35	
Blue clay	35	125	
Sandy blue clay	125	140	22
Grey clay	140	270	
Sandy grey clay	270	280	22
Grey clay	280	350	
Green clay	350	515	
Blue clay	515	550	
Brown sandy clay	550	597	
coarse black sand	597	602	22
Hard brown sandy clay	602	615	
Grey sand	615	620	22
Hard brown clay and gravel	620		

**RECEIVED**  
**JAN 05 1976**

**WATER RESOURCES DEPT.**  
**SALEM, OREGON**

Work started 11, 28, 1975 Completed 12, 17, 1975

Date well drilling machine moved off of well 12, 22, 1975

### Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Norm Sevey Date 12, 27, 1975  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 196

### Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name Norm Sevey Well Drilling  
(Person, firm or corporation) (Type or print)

Address 5619 Leland Dr. Klamath Falls, Oreg. 97601

[Signed] Norm Sevey  
(Water Well Contractor)

Contractor's License No. 408 Date 12, 27, 75, 19\_\_\_\_