

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

*Klamath
14581*

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED

State Well No. 40-190-34ad

State Permit No. DEP 20078

(1) OWNER:

Name LISKEY FARMS INC
Address Box 467
MERRILL, ORE

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dr Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

CASING INSTALLED:

Threaded Welded

" Diam. from ft. to ft. Gage
14" OD " Diam. from +1 ft. to 140 ft. Gage .250
" Diam. from ft. to ft. Gage

PERFORATIONS:

Perforated? Yes No.

Type of perforator used
Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
: gal./min. with ft. drawdown after hrs.
2 LIFT 830 GPM @ 120' " 2 "
" " " " "
Bailer test gal./min. with ft. drawdown after hrs.
sian flow g.p.m.
Temperature of water 89 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT & BENTONITE
Well sealed from land surface to 140 ft.
Diameter of well bore to bottom of seal 20 in.
Diameter of well bore below seal in.
Number of sacks of cement used in well seal 180 sacks
Number of sacks of bentonite used in well seal 6 sacks
Brand name of bentonite AGUAVALL
Number of pounds of bentonite per 100 gallons
of water lbs./100 gals.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of water? COLD depth of strata 95' 125' 135'
Method of sealing strata off CASING & CEMENT
Was well gravel packed? Yes No Size of gravel:
Gravel packed from ft. to ft.

(10) LOCATION OF WELL:

County KLAMATH Driller's well number
SE 1/4 NE 1/4 Section 34 T. 40S R. 9E W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 160 ft.
Static level 13 1/2 ft. below land surface. Date 12/10/76
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 11 1/2

Depth drilled 181 ft. Depth of completed well 181 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
<u>BLACK CLAY TOPSOIL</u>	<u>0</u>	<u>2</u>	
<u>YELLOW CLAY</u>	<u>2</u>	<u>5</u>	
<u>GREEN CLAY</u>	<u>5</u>	<u>6</u>	
<u>HARD GRAY SHALE</u>	<u>6</u>	<u>46</u>	<u>WB</u>
<u>GRAY SHALE</u>	<u>46</u>	<u>160</u>	<u>WB</u>
<u>HARD GRAY SHALE & STREAKS Pumice</u>	<u>160</u>	<u>176</u>	<u>WB</u>
<u>HARD GRAY SHALE</u>	<u>176</u>	<u>181</u>	<u>WB</u>

Work started 12/6/76 19 Completed 12/10/76 19
Date well drilling machine moved off of well 12/10/76 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] Carl M. Stoney Date 12/16, 1976
(Drilling Machine Operator)

Drilling Machine Operator's License No. 656

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name E. ESTOREY & SON WELL DRILLING INC
(Person, firm or corporation) (Type or print)

Address 3847 HOPE K FALLS ORE

[Signed] Carl M. Stoney
(Water Well Contractor)

Contractor's License No. 601 Date 12/16, 1976