NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER RESOURCES DEPARTMENT.
SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON

(Please type or print)

(Do not write above this line)

State Well No. 415/9E-35bc

(1) OWNER:	(10) LOCATION OF WELL:			
Name Mr Jack O. Conner	County Klamath Driller's well number			
Address Lower Klamath Lake, Merrill, Oregon	SW 14 Nw 14 Section 35 T. 41	R. 9E	<u> </u>	W.M.
	Bearing and distance from section or subdivision	on corne	, App	rox.
(2) TYPE OF WORK (check):	2168 Feet North Dad	660		ستوت
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐	Ess of The SW Carre	1 0	5.35	- 141 RYE
If abandonment, describe material and procedure in Item 12.	(11) WATED I EVEL Completed on	-11		
(3) TYPE OF WELL: (4) PROPOSED USE (check):	(11) WATER LEVEL: Completed well. Depth at which water was first found 175 ft.			
Potone T Drivon (7			1. /	ft.
Cable				
Dug Bored I Irrigation X Test Well Other	Artesian pressure lbs. per squar	e inch.	Date *	
CASING INSTALLED: Threaded □ Welded ₹ 250 "Diam. from 0 ft. to 63 ft. Gage 250 "Diam. from ft. to ft. Gage	(12) WELL LOG: Diameter of well below casing 14 Depth drilled 630 ft. Depth of completed well 22 630 ft. Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in			
PERFORATIONS: Perforated? Yes No.	position of Static Water Level and indicate prin	cipal wa	ter-bearir	ng strata.
type of perforator used	MATERIAL	From	To	SWL
Size of perforations in. by in.	Top soil	0	2	
perforations from ft. to ft.	Hard pan sand stone	2	8	
perforations from	Tellow chalk	8	20	
perforations from ft. to ft.	Sand and broken sand stone	20	39	
(E) CORPENIO	Yellow chalk	30	100	
(7) SCREENS: Well screen installed? Yes No	Blue clay	100	175	
Manufacturer's Name	Semi hard grey sand w/ water		180	_115_
Type Model No.	Blue grey clay	180	220	
Diam. ————————————————————————————————————	Yewllow chalk or clay		280	
Diamft. toft.	Grey clay or chalk	280	300	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	Blue grey clay or chalk Grey sand and water crystels		∔30 ≠40	77.
		430 440	500	115
Was a pump test made? Yes \(\sigma\) No If yes, by whom \(\frac{1}{2} \) Pump Yield: 650 gal./min. with 60 ft. drawdown after 4 hrs.	Blue grey clay	500	505	_115_
	Black lava rock	505	525	115
	Blue clay	525	560	
" " "	Grey clay	560	590	
Bailer test gal./min. with ft. drawdown after hrs.	Grey rock shells	590	610	115
Artesian flow g.p.m.	Semi hard stone & clay W/water			115
perature of water 164 Depth artesian flow encounteredft.	Work started Feb 28 19 78 Complete	d Marc	h 30	1978
(9) CONSTRUCTION:	Date well drilling machine moved off of well			1931
Well seal—Material used	Drilling Machine Operator's Certification:			
Well sealed from land surface to63ft.	This well was constructed under my	direct	super	vision.
Diameter of well bore to bottom of seal	Materials used and information reported above are true to my best knowledge and belief.			
Diameter of well bore below seal14 in.	[Signed] (Cally L (Silver Date 4/3] 1978			
Number of sacks of cement used in well seal35 sacks	(Drilling Machine Operator) Drilling Machine Operator's License No. 201			
How was cement grout placed? Poured in.	Drilling Machine Operator's License No.	ــــــــــــــــــــــــــــــــــــــ		······
	Water Well Contractor's Certification:			
	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.			
Was a drive shoe used? ☐ Yes 🏿 No Plugs	Name Wilson DRilling Contractor Inc.			
Did any strata contain unusable water? Yes No	(Person, firm or corporation)	(T;	ype or pri	nt)
Type of water? depth of strata	Address F.O. BOX 150, Merril	7	-ROII	***********
Method of sealing strata off	[Signed] Color To	10/1	lan	······
Was well gravel packed? Yes No Size of gravel:	(Water Well Contr			78
Gravel placed from ft. to ft.	Contractor's License No. 169 Date 4/3	4		, 19