NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

| (Please type or print) TATE ENGINEER (Do not write above this line ALEM. OREGON! |
|--|

| (1) OWNER:   | (10) LOCATION OF WELL:   |
|--|--|
| Name LEON R. PALMER  | County KLAMATA Driller's well number   |
| Address RT 2 Box 650 KLAMATH FALLS, ORE  | 34 34 Section 6 T. 40 S R. /0 E W.M.   |
| 97601  | Bearing and distance from section or subdivision corner  |
| (2) TYPE OF WORK (check):  | 800 N.E. OF THE S.W. CONNER OF SEC. 6  |
| New Well 🔀 Deepening 🗌 Reconditioning 🖺 Abandon 🖂                                      | <u> </u>   |
| If abandonment, describe material and procedure in Item 12.                            | (11) WATER LEVEL: Completed well.  |
| (3) TYPE OF WELL: (4) PROPOSED USE (check):  | Depth at which water was first found /64" ft.  |
| Rotary Driven Domestic M Industrial Municipal Domestic M Industrial Municipal Domestic | Static level /0'4" ft. below land surface. Date / 72-73  |
| D Bored B Irrigation   Test Well   Other   | Artesian pressure lbs. per square inch. Date   |
| (5) CASING INSTALLED: /60 PVC PLASTIC  | (12) WELL LOG: Diameter of well below casing   |
| /  | Depth drilled 2.7 ft. Depth of completed well 2.7 ft.  |
| ft. Gage   |  |
| " Diam. from ft. to ft. Gage   | Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated,   |
| (6) PERFORATIONS: Perforated? Tyes No.   | with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.  |
| Type of perforator used  | MATERIAL From To SWL   |
| Size of perforations in. by in.  | Soil BROWN SAMPY 0 8   |
| perforations fromft. toft.   | CLAY YELLOW P 10   |
| perforations fromft. toft.   | CLAY YELLOU, SAND 10 14 10'4"  |
| perforations fromft. toft.   | CLAY BLUF 14 19  |
| Deliviations Itali   | CLAY BLUE, FINE SAND 19 21   |
| (7) SCREENS: Well screen installed?   Yes No   | GRAVEL, MEDIUM, WATER BEARING 21 26  |
| Manufacturer's Name  | CLAY BLUE 26 26  |
| Type Model No  |  |
| Diam Slot size Set from ft. to ft.   |  |
| Diam. Slot size Set from ft. to ft.  |  |
| (8) WELL TESTS: Drawdown is amount water level is lowered below static level           |  |
| Was a pump test made? Yes \( \sigma \) No If yes, by whom? \( \int R \). PALMER        |  |
| i: 4.5 gal./min. with 12 ft. drawdown after 24 hrs.                                    |  |
| " " "  |  |
| y " " "  |  |
|  | The second of th |
|  |  |
| tesian flow g.p.m.   |  |
| Emperature of water 52° Depth artesian flow encountered ft.                            | Work started /- 22 19 73 Completed 4-22 1973   |
| (9) CONSTRUCTION:  | Date well drilling machine moved off of well 19  |
| Well seal-Material used CEMENT 6-ROUT  | Drilling Machine Operator's Certification:   |
| Well sealed from land surface toft.  | This well was constructed under my direct supervision.  Materials used and information reported above are true to my   |
| Diameter of well bore to bottom of sealin.   | best knowledge and belief.   |
| Diameter of well bore below seal in.   | [Signed] Whey - Date 19  |
| Number of sacks of cement used in well sealsacks                                       | (Drilling Machine Operator) 5/2.  Drilling Machine Operator's License No.  |
| Number of sacks of bentonite used in well seal sacks                                   | Drinning Machine Operator's Incense No.  |
| Brand name of bentonite  | Water Well Contractor's Certification:   |
| Number of pounds of bentonite per 100 gallons  | This well was drilled under my jurisdiction and this report is   |
| of waterlbs./100 gals.   | true to the best of my knowledge and belief.   |
| Was a drive shoe used?   Yes No Plus Size: location ft.                                | Name (Person, firm or corporation) (Type or print)   |
| Did any strata contain unusable water?   Yes   No                                      | )  |
| Type of water? depth of strata   | Address  |
| Method of sealing strata off   | [Signed]   |
| Was well gravel packed? Yes No Size of gravel:   | [Signed] (Water Well Contractor)   |
| Gravel placed fromtt. toft.  | Contractor's License No Date 19  |
| (TICE ADDITIONAL CO  |  |