

NOTICE TO WATER WELL CONTRACTOR: The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

RECEIVED JAN 26 1966 STATE ENGINEER SALEM OREGON G3418

WATER WELL REPORT RECEIVED APR 4 1966 STATE ENGINEER SALEM OREGON

Klam 14776 State Well No. 40/11-32 M State Permit No.

(1) OWNER: Name Marvin Retterath Address Merrill, Oregon

(2) LOCATION OF WELL: County Klamath Driller's well number S W 1/4 S W 1/4 Section 32 T. 40 S R. 11 E W.M. Bearing and distance from section or subdivision corner 1885 feet North of the Said Soth Sec. Line 525 feet east of the said west sec. line

(3) TYPE OF WORK (check): Well [x] Deepening [ ] Reconditioning [ ] Abandon [ ]

(4) PROPOSED USE (check): Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [x] Test Well [ ] Other [ ] (5) TYPE OF WELL: Rotary [ ] Driven [ ] Cable [x] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED: Threaded [ ] Welded [x] 16" Diam. from 0 ft. to 20 ft. Gage 25

(7) PERFORATIONS: Perforated? [ ] Yes [x] No Type of perforator used Size of perforations in. by in. perforations from ft. to ft.

(8) SCREENS: Well screen installed [ ] Yes [x] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION: Well seal—Material used in seal cemented Depth of seal 20 ft. Was a packer used? yes Diameter of well bore to bottom of seal 12 in. Were any loose strata cemented off? [ ] Yes [x] No Depth Was a drive shoe used? [ ] Yes [x] No Was well gravel packed? [ ] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [ ] Yes [x] No Type of water Depth of strata Method of sealing strata off Cemented

(10) WATER LEVELS: Static level 84 ft. below land surface Date 7/6/61 Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [ ] No If yes, by whom? Yield: 500 gal./min. with 3 ft. drawdown after 4 hrs.

(12) WELL LOG: Diameter of well below casing 8 inch Depth drilled 210 ft. Depth of completed well 210 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Top Soil, Brown clay, Brown clay W/ shells of sand, Tan Chalk, Brown and black broken lava (water), Black Lava, Clay W/ gravel, Brown rock, Brown clay w/ gravel, Broken Lava, Brown Chalk, Red lava, Rock w/ crevice (all cuttings washed away), Red lava rock.

Work started July 19 61 Completed July 19 61 Date well drilling machine moved off of well July 19 61

(13) PUMP: Manufacturer's Name Type: H.P.

Water Well Contractor's Certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILSON DRILLING CONTRACTOR (Person, firm or corporation) (Type or print) Address Box 136, Merrill, Oregon Drilling Machine Operator's License No. 122 & 201 [Signed] Walter J. Wilson (Water Well Contractor) Contractor's License No. 369 Date June 19 61