

WATER WELL REPORT
STATE OF OREGON

*Klamath
14795*

RECEIVED State Well No. *405/12E-6ad*

MAR 3 1982

State Permit No. _____
WATER RESOURCES DEPT
SALEM, OREGON

(1) OWNER:

Name Eddie E. Meeker
Address Rt. 2 Box 789
City Klamath Falls State Ore.

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven
Rotary Mud Dug
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other
Thermal: Withdrawal Reinjection

(5) CASING INSTALLED:

Steel Plastic
Riveted Welded
12" Diam. from 0 ft. to 21 ft. Gauge .250

LINER INSTALLED:

" Diam. from _____ ft. to _____ ft. Gauge _____

(6) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____

Size of perforations _____ in. by _____ in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Type _____
Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No. If yes, by whom? valley pump
" 600 gal./min. with 115 ft. drawdown after 4 hrs.

Air test _____ gal./min. with drill stem at _____ ft. _____ hrs.
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m.
Temperature of water 63 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Special standards: Yes No

Well seal—Material used cement
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 18 sacks
How was cement grout placed? grout pipe

Was pump installed? Type _____ HP _____ Depth _____ ft.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of Water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Klamath Driller's well number _____
S.E. 1/4 N. E. 1/4 Section 6 T. 40S R. 12E. W.M. _____
Tax Lot # _____ Lot _____ Blk _____ Subdivision _____
Address at well location: _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 300 ft.
Static level 2 1/2 ft. below land surface. Date 3/18/82
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Depth drilled 460 ft. Diameter of well below casing 12 ft. Depth of completed well 460 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
top soil	1	3	
brown clay & cobbles	3	8	
brown shale	8	10	
28 brown shale & clay	10	28	
gray shale	28	201	
brown clay & shale	201	245	
gray shale	245	280	
brown & blue clay	280	312	2 1/2
gray shale	312	343	"
brown slate	343	350	"
gray basalt	350	354	"
sand stone	354	390	"
gray basalt	390	421	"
brown lava	421	443	"
gray basalt	443	449	"
gray lava & brown clay	449	460	"

Work started 1/27/82 19 _____ Completed 3/15 19 82
Date well drilling machine moved off of well 3/15 19 82

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] John A. Van Meter (Drilling Machine Operator) Date 3/15, 19 82

Drilling Machine Operator's License No. 118

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

Name John A. Van Meter (Type or print)
Address P.O. Box 204 Malin, Ore. 97632

[Signed] John A. Van Meter (Water Well Contractor)

Contractor's License No. 170 Date 3/15, 19 82

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP*12658-690