

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

RECEIVED

WATER WELL REPORT

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion

NOV 25 1980

STATE OF OREGON
(Please type or print)

*Klam
14 829*

State Well No. 405/12E-3166
30
State Permit No. _____

Corrected by WRD staff

WATER RESOURCES DEPT
SALEM, OREGON

(1) OWNER:

Name Carl Rajnus
Address Rt. 2 Box 784 Klamath Falls, Ore. 97601

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
12 " Diam. from 0 ft. to 20 ft. Gage 250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.

Type of perforator used _____
Size of perforations in. by in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level Interstate

a pump test made? Yes No If yes, by whom? pump co.
Yield: 700 gal./min. with 43 ft. drawdown after 2 hrs.
" " " " " "
" " " " " "
Per test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 63 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used cement
Well sealed from land surface to 19 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 12 in. 14
Number of sacks of cement used in well seal _____ sacks
How was cement grout placed? grout pipe

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Klamath Driller's well number _____
N.W. 1/4 N.W. 1/4 Section 31 T. 40S R. 12E. W.M. _____
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 197 ft.
Static level 197 ft. below land surface. Date 11/15/80
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 12
Depth drilled 575 ft. Depth of completed well 575 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
top soil	0	2	
boulders & hardpan	2	4	
brown sandstone	4	29	
brown & gray lava & clay	29	35	
yellow clay & boulders	35	41	
gray sandstone	41	55	
black & white granite	55	76	
yellow clay	76	130	
brown shale	130	233	197
black sandstone	233	391	"
gray sandstone	391	446	"
brown sandstone	446	480	"
black cinders	480	502	"
gray sandstone	502	575	"

Work started 11/29 19 79 Completed 11/15 19 80
Date well drilling machine moved off of well 11/15 19 80

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] John A. Van Meter Date 11/23 19 80
(Drilling Machine Operator) License No. 118

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name John A. Van Meter (Type or print)
(Person, firm or corporation)
Address P.O. Box 204 Malin, Ore. 97632
[Signed] John A. Van Meter (Water Well Contractor)
Contractor's License No. 170 Date 11/23 19 80