

NOTICE TO WATER WELL CONTRACTOR  
The original and first copy  
of this report are to be  
filed with the

**RECEIVED** WATER WELL REPORT

JAN 23 1984

STATE ENGINEER, SALEM, OREGON 97310  
within 30 days from the date  
of well completion.

STATE OF OREGON  
WATER RESOURCES DEPT.  
SALEM, OREGON

Klam  
14893

State Well No. 403/14E-32  
State Permit No.

**(1) OWNER:**

Name Mr & Mrs Ralph Lentz  
Address Langel Valley, Rt 1 Box 109  
Bonanza, Oregon

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

10" Diam. from 0 ft. to 115 ft. Gage 250  
" Diam. from ft. to ft. Gage  
" Diam. from ft. to ft. Gage

**(6) PERFORATIONS:**

Type of perforator used  
Size of perforations in. by in.  
perforations from ft. to ft.  
perforations from ft. to ft.  
perforations from ft. to ft.

**(7) SCREENS:**

Well screen installed?  Yes  No  
Manufacturer's Name  
Type Model No.  
Diam. Slot size Set from ft. to ft.  
Diam. Slot size Set from ft. to ft.

**(8) WELL TESTS:**

Drawdown is amount water level is lowered below static level  
Was a pump test made?  Yes  No If yes, by whom?  
Yield: gal./min. with ft. drawdown after hrs.  
Air lifted 350 G.P.M from 200 feet  
" " " " " "  
Bailer test gal./min. with ft. drawdown after hrs.  
Artesian flow g.p.m.  
Temperature of water Depth artesian flow encountered ft.

**(9) CONSTRUCTION:**

Well seal—Material used 45 Sacks cement  
Well sealed from land surface to 115 ft.  
Diameter of well bore to bottom of seal 14 in.  
Diameter of well bore below seal 10 in.  
Number of sacks of cement used in well seal 45 sacks  
Number of sacks of bentonite used in well seal 20 sacks  
Brand name of bentonite Bentonite  
Number of pounds of bentonite per 100 gallons of water 200 lbs./100 gals.  
Was a drive shoe used?  Yes  No Plugs Size: location ft.  
Did any strata contain unusable water?  Yes  No  
Type of water? depth of strata  
Method of sealing strata off  
Was well gravel packed?  Yes  No Size of gravel:  
Gravel placed from ft. to ft.

**(10) LOCATION OF WELL:**

County Klamath Driller's well number  
1/4 1/4 Section 32 T. 40 S. 14 E W.M.  
Bearing and distance from section or subdivision corner Approx  
1220 feet west and 528 feet North of the  
S.E. Corner of S32 T 40 S R14 E

**(11) WATER LEVEL: Completed well.**

Depth at which water was first found 80 ft.  
Static level 1+ ft. below land surface. Date 2-1-77  
Artesian pressure 1/4 lb lbs. per square inch. Date 2-1-77

**(12) WELL LOG:**

Diameter of well below casing 10  
Depth drilled 5 ft. Depth of completed well 200 ft.  
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Pours Lava rock	185	200	1+
(Hole reamed to 14 inch to 115 feet)			

Work started 1-15 1977 Completed 2-1 1977  
Date well drilling machine moved off of well 2-5 1977

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.  
[Signed] Wilbur J. Zier Date 2-1 1977  
(Drilling Machine Operator)  
Drilling Machine Operator's License No. 201

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Name Wilson Drilling Contractor, Inc.  
(Person, firm or corporation) (Type or print)  
Address P.O. Box 136 Merrill, Oregon  
[Signed] Wilbur J. Zier  
(Water Well Contractor)  
Contractor's License No. 169 Date 2-1 1977